Study of Surface Properties of ATLAS12 Strip Sensors and their Radiation Resistance

M. Mikestikova^{s,*}, P.P. Allport^a, M. Baca^a, J. Broughton^a, A. Chisholm^a, K. Nikolopoulos^a, S. Pyatt^a, J.P. Thomas^a,
J.A. Wilson^a, J. Kierstead^b, P. Kuczewski^b, D. Lynn^b, L.B.A. Hommels^c, M. Ullan^d, I. Bloch^e, I.M.Gregor^e, K. Tackmann^e,
M. Hauser^f, K. Jakobs^f, S.Kuehn^f, K. Mahboubi^f, R. Mori^f, U. Parzefall^f, A. Clark^g, D. Ferrere^g, S. Gonzalez Sevilla^g,
J. Ashby^h, A. Blue^h, R. Bates^h, C. Buttar^h, F.Doherty^h, T.McMullen^h, F.McEwan^h, V. O'Shea^h, S.Kamadaⁱ, K.Yamamuraⁱ,
Y. Ikegami^j, K.Nakamura^j, Y. Takubo^j, Y.Unno^j, R. Takashima^k, A. Chilingarov^l, H. Fox^l, A.A. Affolder^m, G. Casse^m,
P.Dervan^m, D. Forshaw^{m,1}, A. Greenall^m, S. Wonsak^m, M. Wormald^m, V. Cindroⁿ, G. Krambergerⁿ, I. Mandićⁿ, M. Mikužⁿ,
I. Gorelov^o, M. Hoferkamp^o, P. Palni^o, S. Seidel^o, A. Taylor^o, K. Toms^o, R. Wang^o, N.P. Hessey^p, N. Valencic^p,
K. Hanagaki^{q,j}, Z. Dolezal^r, P. Kodys^r, J. Bohm^s, J.Stastny^s, A. Bevan^t, G. Beck^t, C. Milke^u, M. Domingo^u, V. Fadeyev^u,
Z. Galloway^u, D. Hibbard-Lubow^u, Z. Liang^u, H. F.-W. Sadrozinski^u, A. Seiden^u, K. To^u, R. French^v, P.Hodgson^v,
H.Marin-Reyes^v, K. Parker^v, O. Jinnouchi^w, K.Hara^{x,y}, K. Sato^{x,y}, M.Hagihara^x, S. Iwabuchi^x,
J. Bernabeu^z, J.V. Civera^z, C. Garcia^z, C. Lacasta^z, S. Marti i Garcia^z, D. Rodriguez^z, D. Santoyo^z, C. Solaz^z, U. Soldevila^z

^aSchool of Physics and Astronomy, University of Birmingham, Birmingham B15 2TT, United Kingdom

^bBrookhaven National Laboratory, Physics Department and Instrumentation Division, Upton, NY 11973-5000, USA

^cCavendish Laboratory, University of Cambridge, JJ Thomson Avenue, Cambridge CB3 0HE, United Kingdom

^dCentro Nacional de Microelectronica (IMB-CNM, CSIC), Campus UAB-Bellaterra, 08193 Barcelona, Spain

^eDESY, Notkestrasse 85, 22607 Hamburg, Germany

^fPhysikalisches Institut, Universität Freiburg, Hermann-Herder-Str. 3, D-79104 Freiburg, Germany

^gDPNC, University of Geneva, 24, Quai Ernest-Ansermet, CH-1211 Genève 4, Switzerland

^hSUPA- School of Physics and Astronomy, University of Glasgow, Glasgow G12 8QQ, United Kingdom

ⁱSolid State Div., Hamamatsu Photonics K.K., 1126-1, Ichino-cho, Higashi-ku, Hamamatsu-shi, Shizuoka 435-8558, Japan

^jInstitute of Particle and Nuclear Study, KEK, Oho 1-1, Tsukuba, Ibaraki 305-0801, Japan

^kDepartment of Science Education, Kyoto University of Education, Kyoto 612-8522, Japan

^lPhysics Department, Lancaster University, Lancaster LA1 4YB, United Kingdom

^mOliver Lodge Laboratory, Department of Physics, University of Liverpool, Oxford St., Liverpool L69 7ZE, United Kingdom

ⁿJožef Stefan Institute and Department of Physics, University of Ljubljana, Ljubljana, Slovenia

^oDepartment of Physics and Astronomy, University of New Mexico, MSC07 4220, 1919 Lomas Blvd. NE, Albuquerque, NM 87131, USA

^pNikhef, Science Park 105, 1098 XG Amsterdam, Netherlands

^qDepartment of Physics, Osaka University, Machikaneyama-cho 1-1, Toyonaka-shi, Osaka 560-0043, Japan

^rCharles University in Prague, Faculty of Mathematics and Physics, V Holesovickach 2, Prague 8, Czech Republic

^sAcademy of Sciences of the Czech Republic, Institute of Physics, Na Slovance 2, 18221 Prague 8, Czech Republic

^tSchool of Physics and Astronomy, Queen Mary University of London, London E1 4NS, United Kingdom

^uSanta Cruz Institute for Particle Physics (SCIPP), University of California, Santa Cruz, CA 95064, USA

^vDepartment of Physics and Astronomy, The University of Sheffield, Hicks Building, Hounsfield Road, S3 7RH Sheffield, United Kingdom

^wInstitute of Science and Engineering, Tokyo Institute of Technology, Ookayama 2-12-1, Meguro-ku, Tokyo 152-8551, Japan

^xInstitute of Pure and Applied Sciences, University of Tsukuba, Tsukuba, Ibaraki 305-8751, Japan

^yCenter for Integrated Research in Fundamental Science and Engineering, University of Tsukuba, Tsukuba, Ibaraki 305-8571 Japan

^zIFIC/CSIC-UVEG, Ed. Inst. Investigacion, PO Box 22085, 46071 Valencia, Spain

* Corresponding author. e-mail: mikestik@fzu.cz

Abstract

A radiation hard n^+ -in- p micro-strip sensor for the use in the Upgrade of the strip tracker of the ATLAS experiment at the High Luminosity Large Hadron Collider (HL-LHC) has been developed by the “ATLAS ITk Strip Sensor collaboration” and produced by Hamamatsu Photonics.

Surface properties of different types of end-cap and barrel miniature sensors of the latest sensor design ATLAS12 have been studied before and after irradiation. The tested barrel sensors vary in “punch-through protection” (PTP) structure, and the end-cap sensors, whose stereo-strips differ in fan geometry, in strip pitch and in edge strip ganging options. Sensors have been irradiated with proton fluences of up to $1 \times 10^{16} \text{ n}_{\text{eq}}/\text{cm}^2$, by reactor neutron fluence of $1 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$ and by gamma rays from ^{60}Co up to dose of 1 MGy. The main goal of the present study is to characterize the leakage current for micro-discharge breakdown voltage estimation, the inter-strip resistance and capacitance, the bias resistance and the effectiveness of PTP structures as a function of bias voltage and fluence. It has been verified that the ATLAS12 sensors have high breakdown voltage well above the operational voltage which implies that different geometries of sensors do not influence their stability. The inter-strip isolation is a strong function of irradiation fluence, however the sensor performance is acceptable in the expected range for HL-LHC. New gated PTP structure exhibits low PTP onset voltage and sharp cut-off of effective resistance even at the highest tested radiation fluence. The inter-strip capacitance complies with the technical specification required before irradiation and no radiation-induced degradation was observed. A summary of ATLAS12 sensors tests is presented including a comparison of results from different irradiation sites. The measured characteristics are compared with the previous prototype of the sensor design, ATLAS07.

Keywords: HL-LHC, ATLAS ITk, micro-strip sensor, radiation resistance, surface properties, inter-strip capacitance, inter-strip resistance, punch-through protection.

Introduction

The Phase-II upgrade of the Large Hadron Collider (LHC) to the higher luminosity ($5 \times 10^{34} \text{ cm}^{-2} \text{ s}^{-1}$) machine, called the High Luminosity-LHC (HL-LHC) [1], will require replacement of the entire current ATLAS Inner Detector with a new all-silicon tracker containing new type and design of silicon sensors. It will have pixel sensors at the inner radii surrounded by micro-strips. As currently planned, the micro-strip detector in the upgraded Inner Tracker (ITk) [2, 3] will consist of 2 barrel layers of “short” strips (length 23.8 mm), 2 barrel layers of “long” strips (length 47.8 mm) and seven end-cap discs on each side. The end-cap strips length varies from 15 mm to 60 mm depending on the radius. The strip length is chosen so as to maintain the average hit occupancy to be less than 1% at the expected maximum instantaneous luminosity. The maximum hit occupancy is limited by the bandwidth of the read-out system.

Strip sensors in the ITk will be exposed to charged particles, neutrons and gammas. The predicted maximum fluence and ionizing dose [4] for the integrated luminosity of 3000 fb^{-1} in the strip barrels is $5.3 \times 10^{14} \text{ 1-MeV neutron equivalent (n}_{\text{eq}})/\text{cm}^2$ and 216 kGy for the short strips in the layer 1, and in the strip end-caps $8.1 \times 10^{14} \text{ n}_{\text{eq}}/\text{cm}^2$ and 288 kGy in the inner regions of the outermost disk at a distance of 300 cm from interaction point. The estimates stated above have no safety factors applied. Such a high fluence of particles and ionizing dose causes bulk and surface damage to the sensors. In this study the miniature sensors were irradiated by protons, neutrons and gammas from ^{60}Co source. Protons and neutrons displace silicon atoms via non-ionizing energy losses, which results in point and cluster defects in the bulk. In addition

protons ionize both the Si bulk and the insulating layer (SiO₂). The latter causes the accumulation of positive charges and traps in the SiO₂ and at the Si-SiO₂ interface that leads to deterioration of the sensor surface. The gamma irradiation is usually used to study the oxide/interface damage separately from the bulk damage. However, gamma rays from ⁶⁰Co source are absorbed in the sensor mainly through Compton scattering and the scattered Compton electrons have high enough energy (hundreds of keV) to produce point defects in the Si bulk. The surface damage is expected to influence the breakdown voltage, the inter-electrode isolation and capacitance.

The current ATLAS Semi-Conductor Tracker is based on single-sided type of micro-strip sensors made with *p*-strips implanted on *n*-type silicon bulk (*p*-in-*n*). *n*⁺-in-*p* type sensors, which are much more radiation hard [5, 6], are being considered for use in the HL-LHC trackers. This type of sensor has much faster response as it collects electrons instead of holes. It also has no radiation induced type inversion and therefore it always depletes from the segmented side that allows sensor operation in partially depleted mode. This is particularly useful after high radiation fluencies when the full depletion voltage becomes higher. However, *n*⁺-in-*p* strip sensors need additional strip isolation.

A large area *n*⁺-in-*p* silicon sensor for the use in ITk has been developed by the ATLAS ITk Strip Sensor Collaboration [7, 8] and produced by Hamamatsu Photonics (HPK) [9] in a 6-inch (150 mm) wafer. Besides the large sensor (9.75 cm × 9.75 cm), the wafer also includes sets of miniature sensors, which are used for irradiation studies. The sensors were irradiated by different particles, energies and doses and were distributed for extensive test to many institutions of the collaboration for studies of sensor properties that have received up to double maximal fluence predicted in ITk.

The samples for the surface irradiation study presented in this paper are the barrel and end-cap (EC) miniature strip sensors of the latest sensor design, called ATLAS12 [8] which was developed from ATLAS07 design [7]. The surface properties before and after ionizing radiation up to the proton fluence of 1×10^{16} n_{eq}/cm², neutron fluence 1×10^{15} n_{eq}/cm² and gamma dose of up to 1 MGy were evaluated. The tests include measurements of the inter-strip capacitance and resistance as a function of fluence, and the inter-strip resistance as a function of bias, temperature and annealing time. The effectiveness of different types of punch-through protection structures was tested with DC voltage scan method.

Some of the surface studies with previous design ATLAS07 were reported in Ref. [10] to maximal fluence of 1.5×10^{13} n_{eq}/cm². The bulk damage of latest design ATLAS12 is presented in Ref. [11] for barrel and in Ref. [12] for end-cap sensors.

1. Samples and irradiation

The tested sensors of ATLAS12A, ATLAS12M and ATLAS07 layouts¹ are fabricated in *p*-type, float zone wafers with <1 0 0> crystal orientation and thickness of 320 μm. For each layout, slightly different wafer resistivity was used, and therefore the full depletion voltage (*V*_{FD}) differs. The *V*_{FD} of non-irradiated sensors, estimated from capacitance-voltage measurements of strip miniature sensors, was typically 350-360 V for 12A, 225 V for 12M, and 200 V for 07.

The readout aluminum strips are capacitively coupled with *n*-strips biased through polysilicon resistors. The strip isolation is done with common *p*-implant (*p*-stop) with surface ion concentration of approximately 4×10^{12} cm⁻². The tested sensors are ~1×1 cm². The barrel sensors have 74.5 μm strip pitch with various “punch-through protection” (PTP) structure

¹ In ATLAS12A wafer layout the large-area main sensor is made of all “axial” strips where the strips are parallel to the sensor edge. In ATLAS12M two segments of strips are “axial” and two are “stereo” strips where the strips are inclined to the sensor edge. More details about 12A and 12M wafer design are in [8].

geometries examined. The end-cap sensors evaluated here have stereo-strips in fan geometry that differ in strip pitch (“large” and “small” pitches: 103.4 and 64.3 μm on average, respectively) and in edge strip biasing. Details of the design including strip isolation structure and the edge strips ganging are described in Ref. [8].

The proton irradiations were performed at Karlsruhe Inst. Tech., Germany (KIT) [13] with 23 MeV, at Birmingham, UK [14] with 27 MeV and at CYRIC (Tohoku University, Japan) with 70 MeV protons. Samples were kept in a cooled box during irradiations and the box was scanned to cover the whole target area of sensors. The stage scan speed at the CYRIC irradiation was 20 mm/s, at KIT 115 mm/s and at the Birmingham 1 mm/s (2013 irradiation run) and 4 mm/s (2015 run). The scan time depends on the beam current and the area of the samples to be irradiated at the same run. The $10^{15} n_{\text{eq}}/\text{cm}^2$ fluence took 15 minutes at KIT at a beam current 1.7 μA , ~ 80 s in the Birmingham cyclotron at 1000 nA (2013 run), and ~ 100 minutes at CYRIC at 400 nA (2015 run) and at 700 nA (2014 run). The measurement of the equivalent proton fluence has an error of approximately 20 %, taking the precision of the dosimetry and of the estimation of hardness factor into account. The irradiated samples were immediately stored in a refrigerator to prevent any post-irradiated annealing. The neutron irradiations were achieved at Ljubljana JSI TRIGA Reactor [15]. The accuracy of neutron fluence is 10%. The source of uncertainty is the precision of the dosimetry and errors in timing of irradiation. ^{60}Co gamma irradiation was carried out at the Solid State Gamma-ray irradiation facility of the Brookhaven National Laboratory (BNL) [16] and at the Institute of Nuclear Fuels, Prague (UJP) [17]. The sensors were maintained at room temperature during gamma irradiation. The dose rate was 220 Gy/hour and 13.2 kGy/hour in BNL and UJP, respectively. The dose rate uncertainty is $\sim 10\%$ in both cases.

2. Punch-through protection structures

AC coupled strip sensors can be subjected to large voltages between the readout metal strips and the implant strips. These large voltages can be caused by charge accumulation in the bulk due to beam splash accidents. A dedicated punch-through protection (PTP) structure, at the ends of the implant strips is used to keep the implant voltage low. The PTP structure creates a short-circuit in current path in parallel to the bias resistor at the voltages higher than the PTP onset voltage, thus avoiding the capacitor breakdown. The ATLAS12 miniature sensors have different types of PTP structures (A-F type) (Fig. 1) [8]. The E and F types are standard PTP structure with 20 and 70 μm gap between the bias ring and the end of the implant n^+ -strip. The B and C types are new, improved PTP structure with an extended polysilicon electrode of the bias ring over the PTP gap; so called the full-gate structures.

3. Experimental methods and results

About 200 miniature sensors of different types have been tested for surface studies before and after irradiations at silicon laboratories at the Academy of Sciences of the Czech Republic in Prague, University of California Santa Cruz, University of Tsukuba, University of Freiburg, Lancaster University and IFIC Valencia. The sensors were either bonded to PCB board and measured in temperature control box down to -50°C or in probe station with a cooled chuck where the contact was provided by micromanipulators (down to -30°C). Nitrogen environment ensured humidity below 5% at 20°C .

3.1 Leakage current

The leakage current as a function of the bias voltage (IV) was measured for all types of the barrel and end-cap sensors in order to determine whether sensor stability is influenced or not by sensor geometry, wafer used and surface radiation

damage. For all the tested non-irradiated sensors, the value of the leakage current at 600 V is less than 4.8 nA/cm² at 20°C, which is well below the technical specification's limit ($< 2 \mu\text{A}/\text{cm}^2$) [18]. There were no observed onsets of micro-discharges in any of the sensors up to 1000 V.

The left plot of Fig. 2 shows the current of the proton irradiated ATLAS12A, 12M and 07 barrel sensors. The right plot of Fig. 2 shows the current of the end-cap sensors irradiated by protons and gammas. Neutron irradiated barrel sensor is included for comparison. All sensors were measured after annealing them for 80 minutes at 60°C. Most of the proton irradiated sensors did not show micro-discharge breakdown below 1000 V. The wiggle at 250 - 350 V in low fluence samples (0.52 and $1 \times 10^{13} \text{ n}_{\text{eq}}/\text{cm}^2$) is probably due to surface generated current in the backside electrode - when the depletion had reached the backside [8]. The average current values at bias voltage 600 V and temperature -10°C are 30, 51 and 103 $\mu\text{A}/\text{cm}^2$ for the proton fluence 0.5, 1 and $2 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$, respectively. The leakage current increase with fluence is consistent with bulk current increase. The values correspond to what one would expect from the estimate $I(\Phi, t, T) = \alpha(t, T) V \Phi$, where α is the leakage current damage factor², V is the active sensor volume and Φ is fluence in $\text{n}_{\text{eq}}/\text{cm}^2$. Measured current value above fluence of $1 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$ is lower than what is estimated using the sensor volume because sensors are not fully depleted at 600 V. The full depletion voltage increases with increasing proton fluence except for a little variation at low fluence – the V_{FD} decreases up to $1 \times 10^{14} \text{ n}_{\text{eq}}/\text{cm}^2$ due to initial acceptor removal process [21]. The V_{FD} of ATLAS12 sensors is 350-450 V and 500-700 V for 3×10^{14} and $1 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$, respectively. At fluences greater than $3 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$ the V_{FD} is above 1000 V.

The total leakage current increases ~100 times after gamma irradiation, which is the result of the surface current increase due to surface damage. Unfortunately, the guard ring in the tested sensors does not have a probing pad and thus it is not possible to separate the leakage current of the active area inside of the bias ring from the current at the periphery. The micro-discharge breakdown at 900 V of sensors irradiated by 10 kGy gamma dose is attributed to surface damage [22]. It is well above the maximum operating voltage 600 V and it disappears after annealing and additional irradiation. Observation that the current is lower for the higher gamma dose is a subject of further studies.

3.2 Inter-strip capacitance

Important strip sensor surface characteristics which give us information about the effect of surface radiation damage are the inter-strip capacitance (C_{int}) and inter-strip resistance (R_{int}). The inter-strip capacitance contributes to the input capacitance of the readout electronics and is the main contributor to the detector noise. Therefore, it should be as low as possible. The capacitance is measured by LCR meter between a central metal strip and its nearest neighbors with other strips floating (Fig. 3). This way the measurement also includes additional ~10% contribution from the next neighbors [23, 10].

The inter-strip capacitance before irradiation was measured on 25 ATLAS12 sensors at 100 kHz test frequency as required by specifications. The average values of C_{int} are equal to 0.76 ± 0.02 , 0.79 ± 0.01 and $0.55 \pm 0.01 \text{ pF}/\text{cm}$ for barrel, small and large pitch end cap sensors, respectively. The value for the barrel miniature sensors is in very good agreement with value of large area sensor having the same strip pitch [24]. The bias voltage dependence of C_{int} was measured at different proton fluences and gamma doses at test frequency 1MHz³. Fig. 4a shows the results for gamma irradiation. The higher the radiation dose the higher the value of the bias voltage needed for C_{int} to saturate to the pre-radiation value. This is caused by

² $\alpha = 4 \times 10^{-17} \text{ A}/\text{cm}^2$ at 20°C after annealing for $t = 80 \text{ min}$ at 60°C [19]. Bulk current temperature normalization with activation energy of 1.2 eV was used.

³ The inter-strip capacitance measurements are dependent on the frequency of the AC signal. There is a radiation induced resonance at 10 kHz that increases with increasing proton fluence and also affects measurements of C_{int} at 100 kHz [20]. Therefore, for irradiated sensors the higher test frequency of 1MHz was used. The resonance effect is not present at this value.

the surface effect when the increasing charge trapped in the oxide upon irradiation induces an increase in carrier concentration in thin accumulation layer between strips. Beyond V_{FD} the C_{int} becomes constant for both types of irradiation and for all tested doses. C_{int} is not influenced by the PTP structure type. In the case of gamma irradiation, the V_{FD} does not change with irradiation dose, unlike of the proton irradiation. At high proton fluences the depletion depth does not reach the full thickness of the sensor and small increase in values of measured C_{int} at 400 V is probably due to the contribution of the strip-to-backplane capacitance (C_{bulk}) as seen in Figure 4b. Figure 5 shows the C_{int} as a function of proton fluence of ATLAS12A, 12M and 07 measured at various institutions. The inter-strip capacitance is wafer independent and does not change with proton fluence at high bias.

3.3 Inter-strip resistance

A well performing strip sensor has to have a good isolation between the strips in order to maintain the high spatial resolution and adequate signal level of the recorded hits. The isolation between neighboring strips was verified by measurements of the inter-strip resistance (R_{int}). The measuring method is illustrated on Fig. 6. Three adjacent DC pads were contacted. Voltage V_{app} was applied by the Source-Measurement Unit to the central strip and the current I_{int} was measured on the outer strips. The measurements were performed at +20°C for non-irradiated sensors and at cold temperatures (from -10° to -50°C) for irradiated ones. The inter-strip resistance was calculated by

$$R_{int} = 2 / (dI_{int} / dV_{app}).$$

The inter-strip resistance values of non irradiated sensors are tens of GΩ's which significantly exceeds the minimum limit $10 \times R_{bias} \sim 15 \text{ M}\Omega$ required in the technical specification [18]. The inter-strip resistance as a function of bias voltage for ATLAS12A sensors irradiated by protons at different fluences from 1×10^{14} to $1 \times 10^{16} \text{ n}_{eq}/\text{cm}^2$ is shown in Fig. 7. A non-irradiated sample is also shown for comparison. The sensors with PTP structure of type C and E are compared. Before irradiation the inter-strip resistance is independent of bias voltage. After proton irradiation the inter-strip resistance is reduced and is bias voltage dependent. The bias field decreases conductivity between strips. The results of various institutions are consistent. No dependence on PTP structure type was observed.

The inter-strip current as a function of applied voltage for sensors irradiated to different proton fluences is shown in Fig. 8a. The inter-strip current is linear function of applied voltage up to the highest proton fluence $1 \times 10^{16} \text{ n}_{eq}/\text{cm}^2$. The total leakage current is in this case 124 μA. The Fig. 8b presents a comparison of proton and neutron irradiated sensors with the same fluence of $1 \times 10^{15} \text{ n}_{eq}/\text{cm}^2$. Both sensors have a high the total leakage current of 26 μA (at $V_{bias} = -300 \text{ V}$), but the neutron irradiated sensor has a high $R_{int} = 5.28 \pm 0.14 \text{ G}\Omega$, whereas proton irradiated sensor has lower $R_{int} = 0.92 \pm 0.01 \text{ G}\Omega$.

The inter-strip resistance of irradiated sensors is temperature dependent as illustrated in Fig. 9. The inter-strip current has the same temperature dependence as bulk generation current. Using the activation energy of 1.2 eV, the values of inter-strip resistance, normalized to -20°C, are very consistent in the range -10° to -25°C at which sensors were measured in various laboratories (right plot of Fig. 9). In a larger range from 0° to -50°C the inter-strip resistance values are also very close.

The ATLAS12A, 12M and 07 barrel sensors were irradiated in the same irradiation campaign for comparison. Inter-strip resistance as a function of proton fluence measured at various laboratories at the bias voltage 400 V is shown in Fig. 10. All

sensor types have the same inter-strip resistance degradation with proton fluence. Inter-strip resistance values exceed the minimum specs limit up to $3 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$. Up to $1 \times 10^{16} \text{ n}_{\text{eq}}/\text{cm}^2$ the inter-strip resistance is still larger than the pre-amplifier input impedance of $<1 \text{ k}\Omega$ for the ABC130 chip [25].

The correlations between the total ionizing dose (TID) and inter-strip resistance has been studied by comparison of proton, neutron and gamma irradiated sensors. Due to the different damage mechanism caused by proton and gamma in silicon sensor, the proton fluence was converted to TID by:

$$TID = \frac{\Phi[n_{\text{eq}}/\text{cm}^2]}{\kappa} \left(\frac{dE}{dx} \right)_{E_p},$$

where Φ is the proton fluence given by irradiation facilities in 1MeV neutron equivalent, $\left(\frac{dE}{dx} \right)_{E_p}$ is the stopping power of protons of energy E_p in silicon taken from tables in [26] and κ is the conversion damage factor (κ is 1.5, 2.2 and 2 for CYRIC, Birmingham and Karlsruhe irradiation, respectively [27]). In proton irradiated samples the fluence of $1 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$ then corresponds to 0.80, 1.13 and 1.44 MGy for CYRIC, Birmingham and Karlsruhe irradiation, respectively. The TID in neutron irradiated sensors due to secondary particles has been assessed to be 10 kGy for $1 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$ [28]. The dependence of inter-strip resistance on TID is presented in Fig. 11. Gamma and proton irradiated sensors have a similar dependence of inter-strip resistance on the TID, underscoring the influence of the surface damage on the strip isolation. Exceptions are samples from Birmingham 2013 irradiation campaign. This discrepancy is a subject of further studies and tests at the Birmingham facility.

We further sought to check the influence of the bulk damage on the strip isolation by studying neutron irradiated sensors. They have one order of magnitude lower inter-strip resistance than gamma irradiated ones at the same TID. Neutrons in silicon, unlike gammas, cause mainly bulk damage resulting in increased leakage current. The leakage current of gamma irradiated sensors is more than 100 times lower than in neutron ones. Assuming that the TID dose determination for the neutron samples is sufficiently accurate, the difference indicates that the inter-strip resistance may be affected by the bulk damage by its current dependence in addition to the lead effect of the surface damage by TID.

To study the annealing effect on inter-strip resistance, a proton irradiated sensor ($2 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$) was submitted to successive annealing steps at 60°C up to total time of 44000 min. The results of this study are presented in Fig. 12. The annealing of the leakage current is shown for comparison. The leakage current shows typical annealing behavior – decrease at low bias voltage with annealing time and increase at high voltage as charge multiplication (CM) appears at longer annealing. With annealing time the space charge concentration rises and higher electric field near strips causes CM [29]. Inter-strip resistance shows opposite behavior related to leakage current – significant increase at low bias voltage with annealing time and decrease at higher voltage. Annealing for 5000 min causes inter-strip resistance increase to pre-rad value, but the leakage current is still 4 orders of magnitude higher than before irradiation. Charge multiplication near the strips influences the inter-strip resistance at 700 V after annealing for 5000 min and at 400 V at more than 22000 min.

3.4 Coupling capacitance and bias resistance

The coupling capacitance (C_{coupl}) was measured between strip metal and strip implant at 1kHz test frequency. The values of $C_{\text{coupl}}/\text{cm}$ achieved are greater than 24 pF for both non-irradiated and proton irradiated sensors, which meets the specifications of $C_{\text{coupl}}/\text{cm} > 20$ pF [18].

The direct method was used for an estimate of the bias resistance. A current–voltage scan was performed applying voltages (V_{app}) from -1 to +1V in 0.4-V steps to the implant DC pad, and measuring the implant strip current (I_{impl}). I_{impl} is a linear function of applied voltage and resistivity (R_{bias}) was estimated as $R_{\text{bias}} = dV_{\text{app}}/dI_{\text{impl}}$. Gamma and proton irradiated sensors have much lower inter-strip resistance, and inter-strip currents influence the bias resistance measurements. To eliminate these inter-strip effects the voltage V_{test} was applied also on two neighbours, and on next neighbours at the same time. IV was performed on the central strip.

The polysilicon bias resistance of non-irradiated sensors is 1.48 ± 0.07 M Ω which is well within the specification's range ($R_{\text{bias}} = 1.5 \pm 0.5$ M Ω). It slightly increases with proton fluence and gamma dose. However it agrees with the specification up to proton fluence of 3×10^{15} n_{eq}/cm² and gamma dose 1 MGy.

3.5 Stability measurements

Possible time evolution of leakage current and surface parameters is an important operational aspect for strip sensor. Therefore the stability of the leakage current, as well as the inter-strip capacitance and resistance was studied by applying the bias voltage to the sensors for a few hours. Measurements performed at low temperature (from -10° to -25°C) and low humidity verified that the inter-strip capacitance and resistance does not change in time. The leakage current showed relatively small decrease up to 3% during 20 hours in some sensors. The results are in agreement with previous studies for the current Semiconductor tracker of ATLAS experiment [30].

3.6 Punch-through protection

The effectiveness of the punch-through protection structure was tested by using the static DC method [10, 31, 32]. The test voltage V_{test} (0 - 100V) was applied between the implant (DC pad) and the grounded bias rail and resulting current I_{test} was recorded. The I_{test} consists of the punch-through current I_{PTP} and the current flowing through the polysilicon bias resistor (the bias resistance $R_{\text{bias}} \approx 1.5$ M Ω). The punch-through onset voltage $V_{\text{PTP onset}}$ is then defined to be the test voltage at which $I_{\text{PTP}} = 10$ μ A. A well functioning PTP structure demands low $V_{\text{PTP onset}}$, a steep current I_{PTP} increase above $V_{\text{PTP onset}}$ along with maximal current flow below 100 V. The measured current I_{test} as a function of the test voltage for various PTP structure types for proton irradiated sensors at 1×10^{15} n_{eq}/cm² is shown in Fig. 13 while the PTP onset voltage and current at 100 V are shown in Fig. 14.

The full gate structures C and B exhibit the steepest increase in current while keeping $V_{\text{PTP onset}}$ low. In addition the C type have the modest increase of PTP onset voltage up to 2×10^{15} n_{eq}/cm² and large current $I_{\text{PTP}} (@V_{\text{PTP}}=100\text{V})=2.5\text{mA}$ even at 1×10^{16} n_{eq}/cm² (Fig.13 and 14). The novel full gate PTP structure C doubles the allowable current without increasing the onset voltage.

4. Summary and Conclusions

Surface properties of ATLAS12 n^+ -in- p strip sensors intended for upgraded ATLAS ITk fabricated by Hamamatsu were evaluated by several participating institutes to verify if they can cope with predicted high radiation environment.

Different types of barrel and end-cap miniature sensors were tested. Sensors have high micro-discharge breakdown before and after irradiation which is well above the maximum operational voltage (500 V-600 V). The results show that sensor stability is not influenced by PTP structure type, strip pitch, type of edge strip ganging or the wafer used. The inter-strip capacitance of all types of sensors is less than 0.9pF/cm which complies with specifications and does not change with irradiation. The inter-strip resistance decreases with proton, neutron and gamma irradiations. The primary factor is TID dose. However, the inter-strip resistance is also related to the bulk leakage current, that changes with fluence, temperature, and annealing. The values of inter-strip resistance above 100 M Ω for 2×10^{15} n_{eq}/cm² for proton-irradiated samples have proven that the strip isolation is sufficient for HL-LHC fluences. The most suitable PTP structure is the novel PTP structure with an extended electrode of the bias ring over the PTP gap. This full gate structure implemented in the ATLAS12 main sensor, shows a steep current increase above the low onset voltage and low effective resistance at large voltages even at the fluence of 2×10^{15} n_{eq}/cm². Compared to a standard structure without a gate, the new structure doubles the allowable current flowing into bias rail without increasing the onset voltage. Results from the evaluation of various sensor properties are summarized in Table 1.

The present surface studies have demonstrated that developed n⁺-in-p strip sensors of the latest sensor design ATLAS12 show appropriate performance for operation in ATLAS Upgrade ITk.

	Pre- radiation	Protons 1×10^{15} [n _{eq} /cm ²]	Protons 2×10^{15} [n _{eq} /cm ²]	Gamma 100kGy
Leakage current [μ A/cm ²] (at V _{bias} =600V)	<0.0048 (+20°C)	51 (-10°C)	103 (-10°C)	0.22 (+20°C)
Inter-strip capacitance [pF/cm] (at 1MHz)	0.75-0.82	0.82	0.82	0.77
Coupling Capacitance [pF/cm] (at 1kHz)	24	24	24	-
Inter-strip resistance [G Ω /cm] (at V _{bias} =400V)	15-65 (+20°C)	0.5-2.2 (-20°C)	0.3-0.7 (-20°C)	0.0086 (+20°C) 0.6-1.1 (-20°C)
Bias resistance [M Ω]	1.5 $\pm$ 0.1 (+23°C) 1.7-1.8 (-10,-20°C)	2.0 (-20°C)	2.1 (-20°C)	1.7 (+23°C)

Table 1: Summarized measurement values for various sensor properties.

Acknowledgements

The irradiations were performed: with protons at the University of Birmingham MC40 cyclotron, supported by the H2020 project AIDA-2020, GA number 654168, and the UK's Science and Technology Facilities Council, at Cyclotron and Radioisotope Center (CYRIC), Tohoku 45 University, with Y. Sakemi, M. Ito, and T.Wakui, at the Karlsruhe Institute of Technology (KIT) by A.Dierlamm, supported by the Initiative and Networking Fund of the Helmholtz Association, contract HA-101 (Physics at the Terascale) and the European Commission under the FP7 Research Infrastructures project AIDA, Grant agreement no.262025, and at the LANSCE facility, Los Alamos National Laboratory; with neutrons at JSI TRIGA reactor in Ljubljana supported by the H2020 project AIDA-2020, GA no. 654168; and with γ 's at Brookhaven National Laboratory (BNL) and at Institute of Nuclear Fuels (UJP), Prague.

307 The research was supported and financed in part by the Ministry of Education, Youth and Sports of the Czech Republic
308 (Grant No. LG13009), the German Federal Ministry of Education and Research, and the Helmholtz Association, the
309 European Social Fund and by the Ministry of Science, Research and Arts, Baden-Wuerttemberg, Germany, the Japan Society
310 for Promoting Science KAKENHI-A Grant number 20244038 and KAKENHI-C Grant number 20540291, the Ministry of
311 Education, Culture, Sports, Science and Technology-Japan, KAKENHI for Research on Priority Area Grant number
312 20025007 and for Scientific Research on Innovative Areas Grant number 23104002, the Slovenian Research Agency, the
313 Spanish Ministry of Economy and Competitiveness through the Particle Physics National Program (ref. FPA2012-39055-
314 C02-01 and FPA2012-39055-C02-02) and co-financed with FEDER funds, the financial support of the State Secretariat for
315 Education, Research, and Innovation, the Swiss National Science Foundation and the Canton of Geneva, Switzerland, the UK
316 Science and Technology Facilities Council (under Grant ST/M006409/1), and the United States Department of Energy, grant
317 DE-FG02-13ER41983.

318 References

- 319 [1] S. McMahon, 2015. Presented at this symposium.
320 [2] I.-M. Gregor, 2015. Presented at this symposium.
321 [3] ATLAS Collaboration, Letter of Intent Phase II Upgrade, CERN-LHCC-2012-022 LHCC-I-023.
322 [4] I. Dawson and P. Miyagawa, ATL-GEN-2014-003 (2014).
323 [5] G. Casse et al., Nucl. Instr. and Meth. A487 (2002) 465-470.
324 [6] G. Casse et al., IEEE Transactions on Nuclear Science, Vol. 47, N. 3, (2000) 527.
325 [7] Y. Unno et al., Nucl. Instr. and Meth. A636 (2011) S24.
326 [8] Y. Unno et al., Nucl. Instr. and Meth. A765 (2014) 80.
327 [9] Hamamatsu Photonics K.K. <http://www.hamamatsu.com>.
328 [10] S. Lindgren et al., Nucl. Instr. and Meth. A636 (2011) S111.
329 [11] K. Hara et al., 2015. Presented at this symposium.
330 [12] R. Mori et al., 2015. Presented at this symposium.
331 [13] Karlsruhe Institute of Technology, Irradiation center, Hermann-von-Helmholtz-Platz 1, 76344 Eggenstein-Leopoldshafen, Germany,
332 <http://www.ekp.kit.edu/english/264.php>.
333 [14] P. Dervan et al., *The Birmingham Irradiation Facility*, Nucl. Instr. and Meth. A730 (2013) 101.
334 [15] L. Snoj et al., *Applied Radiation and Isotopes* 70 (2012) 483–488.
335 [16] Solid State Gamma-ray irradiation facility, Brookhaven National Laboratory, Instr. Division, 20 N. Technology Street, Upton, NY 11973,
336 <http://www.inst.bnl.gov/facilities/ssif/>.
337 [17] Institute of Nuclear Fuels, UJP Praha, <http://www.ujp.cz/>
338 [18] ATLAS ITk Strip Sensor Collaboration, private communication.
339 [19] M. Moll, Nucl. Instr. and Meth. A426 (1999) 87–93.
340 [20] M. Mikestikova et al., PoS(Vertex2014)050.
341 [21] S. Terada et al., Nucl. Instr. and Meth. A383 (1996)159.
342 [22] K. Hara et al., Nucl. Instr. and Meth. A699 (2013) 107.
343 [23] J. Bohm et al., Nucl. Instr. and Meth. A636 (2011) S104.
344 [24] B. Hommels et al., 2015. Presented at this symposium.
345 [25] J. Kaplon, M. Noy, IEEE Transactions on Nuclear Science, Vol. 59, N. 4 (2012).
346 [26] www.nist.gov
347 [27] A. Vasilescu, G. Lindstroem, *Displacement damage in silicon*, on-line compilation, 2000. <http://rd50.web.cern.ch/RD50/NIEL/default.html>.
348 [28] I. Mandic et al., IEEE Transactions on Nuclear Science, Vol. 51, N. 4 (2004).
349 [29] I. Mandic et al., Nucl. Instr. and Meth, A629 (2011) 101.

[30] A. Chilingarov et al., Nucl. Instr. and Meth. A560 (2006) 118

[31] K. Hara and Y. Ikegami, Nucl. Instr. and Meth. A731 (2013) 242.

[32] K. Hara et al., Phys. Proc. 37 (2012) 838.

Figure 1: PTP structures in ATLAS12 miniature sensors. New PTP structure with full gate (C-type) is implemented in main ATLAS12 sensor in addition to the miniature test sensors.

Figure 2: The leakage current vs. bias voltage after annealing 80 minutes at 60°C for (left) ATLAS12A, 12M and 07 barrel sensors irradiated by protons (CYRIC) to fluences in range 0.52×10^{13} - 8.8×10^{15} n_{eq}/cm^2 taken at -20°C and for (right) various types of ATLAS12 end-cap sensors after proton (Birmingham and Karlsruhe), gamma and neutron irradiation compared with non-irradiated sensor. Proton and neutron sensors were measured at -10°C, gamma and non-irradiated ones at room temperature +20°C [20]. SP and LP in the legend denote for small and large pitch sensors, respectively; E and C are referring to different PTP structure types.

Figure 3: Measuring method for the inter-strip capacitance: AC pads of metal strips are bonded to PCB board. The capacitance between the central strip and its neighbors is measured by an LCR meter in parallel mode.

Figure 4: a) Inter-strip capacitance as a function of bias voltage: ATLAS12A end-cap sensors of small pitch (C and E PTP type) irradiated by gamma. Unirradiated sensor value shown for comparison. Beyond V_{FD} the C_{int} saturates to pre-radiation value. b) Inter-strip capacitance vs. proton fluence measured at bias voltage -400 V and -1000 V: ATLAS12A barrel sensors. The measurements were done at 1 MHz.

Figure 5: Proton fluence dependence of inter-strip capacitance. ATLAS12A, 12M and 07 barrel sensors. $V_{bias} = -1000$ V.

Figure 6: Measurement set-up for inter-strip resistance measurement. The applied voltage was in range (-5V, +5V) for non-irradiated sensors with low inter-strip currents (~ 100 's pA) and (-1V, +1V) for irradiated sensors. Bias voltage was applied to the sensor up to -1000V.

Figure 7: The inter-strip resistance as a function of bias voltage for non- irradiated and proton irradiated (CYRIC) sensors ATLAS12A. The inter-strip resistance values are normalized to -20°C. C and F in the legend denote for PTP structure type, (*) for not annealed sensors.

Figure 8: The inter-strip current as a function of applied voltage: a) comparison of different proton fluences and b) comparison of proton and neutron irradiated sensors to the same fluence of 1×10^{15} n_{eq}/cm^2 . The inter-strip current is linear function of applied voltage.

Figure 9: Temperature dependence of total leakage current (left) and inter-strip resistance (middle) measured in temperature interval from -50 to 0°C. Inter-strip resistance is normalized to -20°C using $E_a = 1.2$ eV (right). The measured sample is ATLAS12M barrel sensor irradiated to fluence of 1×10^{15} n_{eq}/cm^2 .

Figure 10: Inter-strip resistance vs. proton fluence for ATLAS12A, 12M and 07 barrel samples irradiated in the same irradiation campaign at CYRIC and measured by various laboratories at bias voltage of -400 V. The results are normalized to temperature of -20°C.

Figure 11: Inter-strip resistance vs. total ionizing dose for ATLAS12 sensors irradiated by protons, neutrons and gammas at different irradiation sites. Results at bias voltage -400V are presented. The values are normalized to the temperature of -20°C.

Figure 12: The leakage current (left) and the inter-strip resistance (middle) measured at different annealing time at 60°C, inter-strip resistance vs. annealing time (right) measured at 400 V and 700 V. ATLAS12A sensor irradiated by proton fluence 2×10^{15} n_{eq}/cm^2 (Karlsruhe) was studied. The arrows in the left and middle plot indicate the data trends with the annealing time.

Figure 13: Current I_{test} as a function of applied test voltage V_{test} for different types of PTP structures (A-F) implemented in ATLAS12M sensors. Sensors were irradiated by protons to fluence of 1×10^{15} n_{eq}/cm^2 and measured at bias voltage 1000 V and temperature -20°C.

Figure 14: PTP onset voltage (upper left) and test current at 100V (upper right) for different types of PTP structures in sensors irradiated to 1×10^{15} n_{eq}/cm^2 . Fluence dependence of V_{PTP} (bottom left) and I_{test} (bottom right) of PTP structure C.

Figure 1

Figure 2a

Figure 2b

Figure 3

Figure 4a

Figure 4b

Figure 5

Figure 6

Figure 7

Figure 8a

Figure 8b

Figure 9

Figure 10

Figure 11

Figure 12

Figure 13

Figure 14