A Mixed Integer Linear Programming Approach for Optimal DER Portfolio, Sizing, and Placement in Multi-Energy Microgrids

Salman Mashayekh, Michael Stadler, Gonalo Cardoso, and Miguel Heleno
Ernest Orlando Lawrence Berkeley National Lab, 1 Cyclotron Rd, MS: 90-1121, Berkeley, CA 94720
Corresponding Author: Michael Stadler (MStadler@lbl.gov)

Abstract: Optimal microgrid design is a challenging problem, especially for multi-energy microgrids with electricity, heating, and cooling loads as well as sources, and multiple energy carriers. To address this problem, this paper presents an optimization model formulated as a mixed-integer linear program, which determines the optimal technology portfolio, the optimal technology placement, and the associated optimal dispatch, in a microgrid with multiple energy types. The developed model uses a multi-node modeling approach (as opposed to an aggregate single-node approach) that includes electrical power flow and heat flow equations, and hence, offers the ability to perform optimal siting considering physical and operational constraints of electrical and heating/cooling networks. The new model is founded on the existing optimization model DER-CAM, a state-of-the-art decision support tool for microgrid planning and design. The results of a case study that compares single-node vs. multi-node optimal design for an example microgrid show the importance of multi-node modeling. It has been shown that single-node approaches are not only incapable of optimal DER placement, but may also result in sub-optimal DER portfolio, as well as underestimation of investment costs.

Keywords

Multi-energy microgrid design, power flow, electrical network, heating and cooling network, mixed-integer linear program

1 Nomenclature

Decision variables and parameters are denoted with italic and non-italic fonts, respectively. Binary/integer variables are denoted with all-small letters. Vectors and matrices are denoted with bold small case letters and bold capital case letters, respectively.

1.1 Sets and Indices

t	time (1, ..., $12 \times 3 \times 24$): 12 months, 3 day-types per month, and 24 hours per day-type
m	month (1, ..., 12)
u	energy use: electricity (EL), cooling (CL), heating (HT)
c	generation technologies whose capacities are modeled with continuous variables (referred to as continuous generation technologies in this paper): photovoltaic (PV), solar thermal (ST), electric chiller (EC), boiler (BL), absorption chiller (AC)

34	g	generation technologies whose capacities are modeled with discrete variables (referred
35		to as discrete generation technologies in this paper): internal combustion engine (ICE),
36		micro-turbine (MT), fuel cell (FC)
37	s	storage technologies: electric storage (ES), heat storage (HS), cold storage (CS)
38	j	all generation technologies ($g \cup c$)
39	k	generation and storage technologies whose capacities are modeled with continuous
40		variables (referred to as continuous technologies in this paper) ($c \cup s$)
41	i	all generation and storage technologies ($g \cup c \cup s$)
42	p	period of day (for tariff): on-peak, mid-peak, and off-peak
43	n, n'	electrical/thermal nodes (1,2, ..., N): n and n' are aliases

44 1.2 Electrical and Thermal Network Parameters

45	N	number of nodes (electrical/thermal)
46	$r_{n,n'}, x_{n,n'}$	resistance/inductance of the line connecting node n to n' , i.e. line (n, n') , pu
47	$Y_{r,n,n'}, Y_{i,n,n'}$	real/imaginary term of Y_{bus} for line (n, n') , pu
48	$Z_{r,n,n'}, Z_{i,n,n'}$	real/imaginary term of Z_{bus} for line (n, n') , pu
49	S_b	base apparent power, kVA
50	V_0	slack bus voltage, pu
51	$\underline{V}, \bar{V}$	minimum/maximum acceptable voltage magnitude, pu
52	$\underline{\theta}, \bar{\theta}$	minimum/maximum expected voltage angle, rad
53	N_v	number of segments for linearization of current magnitude squared
54	$\bar{I}_{r,n,n'}, \bar{I}_{i,n,n'}$	maximum expected value of the real/imaginary current of line (n, n') , pu
55	$\bar{I}_{n,n'}$	current carrying capacity (ampacity) of line (n, n') , pu
56	$\bar{S}_{n,n'}$	power carrying capacity of line (n, n') , pu
57	ϕ	generation/load power factor
58	$\gamma_{n,n'}$	heat loss coefficient for heat transfer pipe (n, n') , %/m
59	$\overline{HtTr}_{n,n'}$	heat transfer capacity for pipe (n, n') , kW

60 1.3 Market and Tariff Data

61	grd	binary parameter for the existence of a grid connection
62	$CurPr_{n,u}$	load curtailment cost for energy use u at node n , \$/kWh
63	$CTax$	tax on carbon emissions (onsite and offsite), \$/kg
64	$DmnRt_{m,p}$	power demand charge for month m and period p , \$/kW
65	$ExpRt_t$	energy rate for electricity export, \$/kWh
66	$PurRt_t$	energy rate for electricity purchase, \$/kWh
67	$\overline{UtExp}$	maximum allowable electricity export to the grid, kW

68 1.4 Technology Data for Investment

69	Ann_i	annuity rate for technology i
70	$CFix_k$	fixed capital cost of continuous technology k , \$
71	$CVar_k$	variable capital cost of continuous technology k , \$/kW
72	$\overline{DERP}_g$	power rating of discrete generation technology g , kW

73	$DERCap_g$	turnkey capital cost of discrete generation technology g , \$/kW
74	1.5 Technology Data for Operation	
75	$COP_a, COPE$	absorption/electric chiller coefficient of performance
76	$DERMF_{x_i}$	fixed annual operation and maintenance cost of technology i , \$/kW-capacity
77	$DERMVR_i$	variable annual operation and maintenance cost of technology i , \$/kWh
78	$DERGn_{Cst_j}$	generation cost of technology j , \$/kWh
79	$SolEff_{c,t}$	solar radiation conversion efficiency of generation technology $c \in \{PV, ST\}$
80	$ScPkEff_c$	theoretical peak solar conversion efficiency of generation technology $c \in \{PV, ST\}$
81	$SCEff_s, SDEff_s$	charging/discharging efficiency of storage technology s
82	$\overline{SCRt}_s, \overline{SDRt}_s$	max charge/discharge rate of storage technology s , kW
83	$\overline{SOC}_s, \overline{SOC}_s$	min/max state of charge for storage technology s , %
84	φ_s	losses due to self-discharge in storage technology s , %
85	α_j	useful heat recovery from a unit of electricity generated by technology j , kW/kW
86	η_j	electrical efficiency of generation technology j
87	$MkCRt_t$	marginal carbon emissions from marketplace generation, kg/kWh
88	$GCrt_j$	carbon emissions rate from generation technology j , kg/kWh
89	1.6 Site and Location Parameters	
90	$Solar_t$	average fraction of maximum solar insolation received during time t , %
91	$Ld_{n,u,t}$	customer load for end-use u at node n , kW
92	1.7 Decision/State Variables for Investment	
93	$pur_{n,k}$	binary purchase decision for continuous technology k at node n
94	$Cap_{n,k}$	installed capacity of continuous technology k at node n , kW or kWh
95	$inv_{n,g}$	integer units of discrete generation technology g at node n
96	1.8 Decision/State Variables for Operation	
97	$psb_{n,t}$	binary electricity purchase/sell decision at node n
98	$UExp_{n,t}$	electricity exported to the utility at node n , kW
99	$UPur_{n,t}$	electricity purchased from the utility at node n , kW
100	$MaxPur_{n,m,p}$	maximum electricity purchased from the utility during period p of month m , kW
101	$SOC_{n,s,t}$	state of charge for storage technology s at node n , %
102	$SIn_{n,s,t}$	energy input to storage technology s at node n , kWh
103	$SOut_{n,s,t}$	energy output from storage technology s at node n , kWh
104	$LdCur_{n,u,t}$	customer load not met in energy use u at node n , kW
105	$Gen_{n,j,u,t}$	output of technology j to meet energy use u at node n , kW
106	$HtTr_{n,n',t}$	heat flow from node n to n' , kW
107	$Vr_{n,t}, Vi_{n,t}$	real/imaginary voltage at node n , pu
108	$Pg_{n,t}, Qg_{n,t}$	injected active/reactive power at node n , pu
109	$Sg_{n,t}$	injected apparent power at node n , pu
110	$Ploss_t, Qloss_t$	network active/reactive power loss at time t , pu
111	$S_{n,n',t}$	apparent power of line (n, n') , pu

112	$I_{r_{n,n',t}}, I_{i_{n,n',t}}$	real/imaginary current of line (n, n'), pu
113	$I_{rSq_{n,n',t}}$	linear approximation of $ I_{r_{n,n',t}} ^2$, pu ²
114	$I_{iSq_{n,n',t}}$	linear approximation of $ I_{i_{n,n',t}} ^2$, pu ²

115 2 Introduction

116 The attention towards microgrids is constantly increasing with a fast pace, as a result of their benefits in
117 terms of renewable integration, low carbon footprint, reliability and resiliency, power quality, and
118 economics. Global environmental concerns are pushing forward and providing incentives for the
119 deployment of renewable energy technologies, e.g. photovoltaics (PV) and wind. Most developed
120 countries have set their renewable penetration goals. As a consequence, renewable energy technologies
121 are rapidly advancing towards lower costs and higher efficiencies, making their deployments even more
122 compelling. Also, resiliency concerns in the face of natural disasters have made (islandable) microgrids
123 more popular, especially for critical facilities. The NY REV (New York's Reforming of the Energy Vision)
124 Initiative [1] is an example of amplified attention towards microgrids, following big disruptions caused
125 by the Hurricane Sandy in the US North East. Microgrids provide benefits to the utilities, too, since they
126 are a much better alternative compared to distributed and uncoordinated deployment of renewable
127 energy resources.

128 A microgrid offers a cluster of small sources, storage systems, and loads, within clearly-defined electrical
129 boundaries, which presents itself to the main grid as a single, flexible, and controllable entity [2]. By
130 introducing on-site generation, storage, and bidirectional power flow, microgrids can be seen as a
131 valuable resource to the grid, while also being more independent from it [3]. This flexible resource, if
132 optimally designed and operated, also provides cost saving benefits to the customers. Microgrids,
133 however, are complex energy systems that require specific infrastructure, resource coordination, and
134 information flows [3], and the complexity increases in the presence of technologies that tie together
135 electrical, heating, and cooling energy flows. Such multi-energy microgrids with combined heat and
136 power (CHP) and absorption chilling offer better efficiencies and savings through utilization of waste
137 heat [4],[5]. The high level of complexity and the potential for cost savings, when also factoring in the
138 high investment cost of microgrids, will help appreciate the challenging problem of microgrid design,
139 especially for multi-energy microgrids (i.e., microgrids in which electricity, heat, cooling, and fuels
140 interact with each other, presenting the opportunity to enhance technical, economic and environmental
141 performance [6]).

142 Several papers in the literature have reviewed the existing tools and computer models for renewable
143 energy integration and microgrid planning and design [7-12]. A comprehensive microgrid investment
144 and planning optimization formulation must address a) power generation mix selection and sizing, b)
145 resource siting and allocation, and c) operation scheduling [10]. In order to take full advantage of excess
146 heat it must simultaneously consider electricity, cooling, and heating energy uses in the microgrid.
147 However, most of the existing formulations focus on individual sub-problems and do not include the
148 whole set of problems or include them without enough depth. Table 1 provides a summary of the recent
149 developments in the distributed energy system design approaches and shows the lack of a tool
150 encompassing all of the aforementioned pieces.

On one side of the spectrum are formulations that include details of the electrical network and do not consider the thermal network. Among them are some of the distribution network planning formulations that consider distributed and renewable energy resources (DER). A review of optimal distributed renewable generation planning approaches is provided in [13]. These formulations [14-16] share some of the same characteristics with the microgrid design problem, mainly since they determine the size and location of DERs to be installed and the optimal dispatch associated with the upgraded network. However, the generation mix is limited and the focus is only on electrical energy use. Similarly, some microgrid design formulations [17],[18] only tackle electrical energy, neglecting heating and cooling energy uses. On the other side of the spectrum, district or neighborhood-level heating design optimization formulations focus on the thermal energy and its flow in the network, but do not consider electrical energy use, e.g. [19-21]; or take electrical energy use into account but neglect the electrical network, e.g. [22-24], weakening the ability to perform DER optimal placement.

References [25-31] feature microgrid design formulations that model (to some extent) both electrical and thermal networks and present the most relevant work to this paper. Omu et. al. [25] formulated a mixed integer linear program for optimum technology selection, unit sizing and allocation, and network design of a distributed energy system that meets the electricity and heating demands of a cluster of buildings. This work, however, models electrical energy as a commodity whose transfer from one location to another can be arbitrarily decided, neglecting power flow constraints or Kirchhoff laws. Similarly, the approaches presented in [26-28] for design and planning of urban and distributed energy systems do not include power flow equations. Yang et. al. [29] proposed another approach for integrated design of heating, cooling, and electrical power distribution networks, but did not include electrical power flow equations.

In another example, Morvaj et. al. [30] developed a mixed integer linear program for the optimal design of distributed energy systems, in which linearized AC power flow equations and heat transfer equations were integrated, but cooling energy use was neglected. Similarly, Basu et. al. [31] proposed an approach to optimally determine the size, location, and type of CHP-based DERs in microgrids, using power loss sensitivity to guide the optimization in siting the DERs. Although both electrical and heating energy uses and networks are modeled, cooling is neglected. Also, the formulation is nonlinear and solves using a stochastic approach. Unlike linear formulations, nonlinear formulations do not efficiently scale and it is not guaranteed to find the best solution.

Table 1 Summary of the most relevant formulations in the current literature

Ref.	Energy Use			Electrical Distribution Network		Heat Transfer Network
	Electricity	Heating	Cooling	Capacity Constraints	Voltage Constraints (Power Flow Equations)	Capacity Constraints
[14]	x			x	x	
[15]	x			x	x	
[16]	x			x	x	
[17]	x			x	x	
[18]	x			x	x	
[19]		x				x
[20]		x				x
[21]		x				x
[22]	x	x				x
[23]	x	x				x
[24]	x	x				x
[25]	x	x		x		x
[26]	x	x		x		x
[27]	x	x		x		x
[28]	x	x		x		x
[29]	x	x	x	x		x
[30]	x	x		x	x	x
[31]	x	x		x	x	x
This Paper	x	x	x	x	x	x

This paper builds on the existing work in the literature, and formulates the problem of optimal design (DER sizing, allocation, and operation) of microgrids as a mixed integer linear program. The contributions of this work are threefold:

- First, we propose an integrated design approach in which electrical, heating, and cooling loads and sources are modeled, in order to take full advantage of excess heat in the microgrid and enhance the overall system efficiency.
- Second, our formulation considers the limitations of the electrical and heat transfer networks in the design and dispatch, allowing for the optimal placement of the DER technologies. To this end, we integrate a set of linear heat transfer equations that include network losses. We also integrate a set of linearized AC power flow equations into the problem that model active and reactive power flow in the network and hence, allows imposing of cable capacity and bus voltage constraints.
- Third, since minimization of network losses is one of the important factors in optimal technology placement, we propose a novel approach to integrate a linear approximation of electrical network active and reactive power losses into the optimization problem.

This paper is organized as follows. Section 3 presents the developed model for the optimal microgrid design problem and discusses the details of the optimization objective and constraints. Next, an illustrative case study is presented in section 4 and the results are elaborated. The paper summary and future work are provided in section 5.

3 Developed Optimization Model

We present the mathematical formulation for the integrated design of multi-energy microgrids. The presented model is founded on the existing optimization model in DER-CAM (Distributed Energy Resources Customer Adoption Model) [32], developed by Lawrence Berkeley National Laboratory. DER-CAM is used extensively to address the problem of optimal investment and dispatch of microgrids under multiple settings. DER-CAM is one of the few optimization tools of its kind that is available for public use and stable versions can be accessed freely using a web interface [33]. The key inputs in DER-CAM are customer loads, utility tariffs, and techno-economic data for DER technologies. Key optimization outputs include the optimal installed on-site capacity and dispatch of selected technologies, demand response measures, and energy costs.

The new model proposed in this paper alleviates the need to iterate between a microgrid optimization-based design tool and an electrical power flow tool or a heat transfer modeling tool since it considers the microgrid's electrical and thermal networks and their limitations. To enable reasonable and practical optimization run times, we formulate the problem in the form of a mixed integer linear program. To that end, component and network models are simplified and linearized. Our previous analysis of the existing models in DER-CAM [34-36] and our analysis of the new models developed in this paper (presented in section 4) ensure the adequacy of the models and validate the simplifications.

3.1 Microgrid Model

We consider a general microgrid structure as shown in Figure 1 with electrical and thermal networks. The electrical network can be either meshed or radial. Similarly, the piping network can have any arbitrary configuration. The microgrid may or may not have a utility connection. The load at each node is composed of several end-uses including electricity-only (mainly plug loads), heating (water and space heating), and cooling loads. The objective is to determine the optimal portfolio, capacity, and placement of various DER technologies that minimize the overall investment and operation cost of the microgrid, while taking into account electrical and thermal network losses and constraints, as well as operational limits of various technologies.

Figure 1 General microgrid model with electrical (meshed or radial) and thermal (arbitrary configuration) networks, with or without utility connection

3.2 Continuous vs. Discrete Investment Decision Variables

We model DER capacities for different technologies using a continuous or discrete variable: If a technology is available in small enough modules and the capital costs can be represented by a linear cost function, the optimal capacity to be installed is modeled as a continuous variable, significantly lowering computational time. These technologies are referred to as *continuous technologies* in this paper. Examples of continuously modeled DER technologies are PV, battery, and absorption chilling. Discrete variables are used otherwise. These technologies are referred to as *discrete technologies* in this paper. Examples of discrete generation technologies are internal combustion engines and micro-turbines. Each node in Figure 1 can host continuous technologies (for which $Cap_{n,k}$ is the capacity to be installed) and discrete technologies (for which $inv_{n,g}$ is the number of units to be installed).

3.3 Time Resolution

The total investment and operation costs are minimized over a typical year, where each month is modeled with up to three representative hourly load profiles of a) week day, b) weekend day, and c) peak day (outlier). Therefore, a typical year is modeled with $12 \times 3 \times 24 = 864$ time-steps. Due to the hourly time-step, energy and power are numerically identical.

3.4 Objective Function

The objective is to minimize the overall microgrid investment and operation cost, though it is also possible to minimize emissions, or a combination of costs and emissions. Equation (1) shows that the objective function includes: annualized investment costs of discrete and continuous technologies; total cost of electricity purchase inclusive of carbon taxation; demand charges; electricity export revenues; generation cost for electrical, heating, or cooling technologies inclusive of their variable maintenance costs; fixed maintenance cost of discrete and continuous technologies; carbon taxation on local generation; and load curtailment costs.

$$\begin{aligned}
C = & \sum_{n,g} inv_{n,g} \cdot \overline{DERP}_g \cdot DERCap_g \cdot Ann_g \\
& + \sum_{n,k} (CFix_k \cdot pur_{n,k} + CVar_k \cdot Cap_{n,k}) \cdot Ann_k \\
& + \sum_{n,t} UtilPur_{n,t} (PurRt_t + CTax \cdot MkCrt_t) \\
& + \sum_{n,m,p} DmnRt_{m,p} \cdot MaxPur_{n,m,p} \\
& - \sum_{n,t} ExpRt_t \cdot UtExp_{n,t} \\
& + \sum_{n,j,t} Gen_{n,j,t} (DERGnCst_j + DERMVr_j) \\
& + \sum_{n,g} inv_{n,g} \cdot \overline{DERP}_g \cdot DERMFx_g + \sum_{n,k} Cap_{n,k} \cdot DERMFx_k \\
& + \sum_{n,j,t} Gen_{n,j,t} \cdot \frac{1}{\eta_j} \cdot GCrt_j \cdot CTax \\
& + \sum_{n,u,t} LdCur_{n,u,t} \cdot CurPr_{n,u}
\end{aligned} \tag{1}$$

3.5 Electrical Balance

To integrate electrical balance equations for the network, i.e. electrical power flow, an explicit linear model was adopted [37] that approximates node (bus) voltages in meshed/radial balanced distribution networks. Equations (4)-(6) show how real and imaginary terms of node voltages are calculated for non-slack and slack buses in the Cartesian coordinates, based on the network impedances and node injection powers. We assume the microgrid's slack (reference) bus is the last node, i.e. node N, and its voltage is fixed at $V_0 \angle 0^\circ$ as shown in (6).

The net injected power at a node, as shown in (2), takes into account utility import and export at the node, local generation at the node, load and load curtailment, electric chiller consumption at the node, and battery charging or discharging. To simplify the formulation presentation, we assume a constant power factor ϕ for all power injections, as shown in (3). This assumption, however, can be easily expanded to consider different power factors for various loads and DERs.

$$\begin{aligned}
Sb \cdot Pg_{n,t} = & UtPur_{n,t} - UtExp_{n,t} \\
& + \sum_{j \in \{PV, ICE, MC, FC\}} Gen_{n,j,t} \\
& - (Ld_{n,u=EL,t} - LdCur_{n,u=EL,t}) - \frac{1}{COPE} \cdot Gen_{n,c=EC,t} \\
& + SOut_{n,s=ES,t} \cdot SDEff_{s=ES} - \frac{1}{SCEff_{s=ES}} \cdot Sin_{n,s=ES,t}
\end{aligned} \tag{2}$$

$$Qg_{n,t} = Pg_{n,t} \cdot \tan(\cos\phi); \quad n \neq N \tag{3}$$

$$Vr_{n,t} = V_0 + \frac{1}{V_0} \sum_{n' \neq N} (Zr_{n,n'} \cdot Pg_{n',t} + Zi_{n,n'} \cdot Qg_{n',t}); \quad n \neq N \tag{4}$$

$$Vi_{n,t} = V_0 + \frac{1}{V_0} \sum_{n' \neq N} (Zi_{n,n'} \cdot Pg_{n,t} - Zr_{n,n'} \cdot Qg_{n,t}) ; \quad n \neq N \quad (5)$$

$$Vr_{n,t} = V_0, \quad Vi_{n,t} = 0 ; \quad n = N \quad (6)$$

265 The existence of the practical approximate power flow solution in (4)-(6) requires the network to meet
266 the condition

$$267 \quad V_0^2 > 4 \cdot \|Z\|^* \cdot \|s_t\|,$$

268 in which Z is the network Zbus matrix without the slack bus row and column, and s_t is the vector of
269 apparent power injections for non-slack buses. The standard 2-norm $\|\cdot\|$ for the vector s_t is defined as

$$270 \quad \|s_t\| \triangleq \sqrt{\sum_{n \neq N} |Sg_{n,t}|^2}.$$

271 Also, the norm $\|\cdot\|^*$ for a matrix is defined as the maximum of the 2-norm values of its row vectors [37].
272 We refer to this constraint as the “approximate power flow existence condition” in this paper.

273 In the above condition, V_0^2 and $\|Z\|^*$ are parameters known before solving the optimization (i.e., fixed
274 parameters). However, $\|s_t\|$ at any given time t depends on the dispatch, and will not be known until
275 after solving the optimization. To ensure the validity of the integrated power flow model for a microgrid
276 under study, we propose two options: The first option is to assume the model is valid and run the
277 optimization. Then assess the criterion based on the optimization results (post-optimization
278 assessment). Alternatively, in the second option we will find (in the following paragraph) an upper
279 bound for the $\|s_t\|$, which can be used to develop a *sufficient* condition.

280 The injection at a bus is limited by the capacity of the lines connected to the bus as shown in (7), setting
281 an upper bound for the $\|s_t\|$ as shown in (8). Consequently, the sufficient condition of (9) is obtained
282 that can be assessed using only the network parameters (which are known before solving the
283 optimization).

$$Sg_{n,t} = \sum_{n'} S_{n,n',t} \rightarrow |Sg_{n,t}| \leq \sum_{n'} |S_{n,n',t}| \leq \sum_{n'} \bar{S}_{n,n'} \quad (7)$$

$$\|s_t\| \leq \sqrt{\sum_{n \neq N} \left(\sum_{n'} \bar{S}_{n,n'} \right)^2} \quad (8)$$

$$\sqrt{\sum_{n \neq N} \left(\sum_{n'} |\bar{S}_{n,n'}| \right)^2} \leq \frac{1}{4 \cdot \|Z\|^*} \cdot V_0^2 \quad (9)$$

284

285 One of the important factors that drives the optimal placement of distributed energy resources is the
286 minimization of network losses. To account for losses in this formulation, we add equation (10) that
287 ensures total active/reactive power injection (generation minus consumption) equals total

288 active/reactive power loss in the system. To calculate network losses in (11)-(12) we use $IrSq_{n,n',t}$ and
 289 $IiSq_{n,n',t}$ that are linear approximations of $|Ir_{n,n',t}|^2$ and $|Ii_{n,n',t}|^2$, respectively, and will be discussed in
 290 section 3.6.

$$\sum_n P_{g_{n,t}} = P_{loss_t}, \sum_n Q_{g_{n,t}} = Q_{loss_t} \quad (10)$$

$$P_{loss_t} = \frac{1}{2} \sum_{n,n'} r_{n,n'} \cdot (|Ir_{n,n',t}|^2 + |Ii_{n,n',t}|^2) \approx \frac{1}{2} \sum_{n,n'} r_{n,n'} \cdot (IrSq_{n,n',t} + IiSq_{n,n',t}) \quad (11)$$

$$Q_{loss_t} = \frac{1}{2} \sum_{n,n'} x_{n,n'} \cdot (|Ir_{n,n',t}|^2 + |Ii_{n,n',t}|^2) \approx \frac{1}{2} \sum_{n,n'} x_{n,n'} \cdot (IrSq_{n,n',t} + IiSq_{n,n',t}) \quad (12)$$

291 3.6 Cable Current Constraints

292 To integrate cable current capacity (ampacity) constraints, (13)-(14) calculate the real and imaginary
 293 terms of the current in the Cartesian coordinates. To estimate $|Ir|^2$ and $|Ii|^2$, the square curve is
 294 piecewise linearized and relaxed as shown in Figure 2. Consequently, $IrSq$ and $IiSq$ are calculated using
 295 a series of linear inequality equations, as shown in (15)-(18). Equations (15) and (16) are for the positive
 296 and negative values of Ir , respectively. Similarly, (17) and (18) are related to the positive and negative
 297 values of Ii . ΔIr and ΔIi in these equations are calculated in (19). Equation (20) enforces the ampacity
 298 constraint. As mentioned earlier, $IrSq$ and $IiSq$ are used for loss estimation, too.

$$Ir_{n,n',t} = -Y_{r,n,n'} \cdot (V_{r,n,t} - V_{r,n',t}) + Y_{i,n,n'} \cdot (V_{i,n,t} - V_{i,n',t}) \quad (13)$$

$$Ii_{n,n',t} = -Y_{i,n,n'} \cdot (V_{r,n,t} - V_{r,n',t}) - Y_{r,n,n'} \cdot (V_{i,n,t} - V_{i,n',t}) \quad (14)$$

$$IrSq_{n,n',t} \geq (v \cdot \Delta Ir)^2 + (2v - 1) \cdot \Delta Ir \cdot (Ir_{n,n',v,t} - v \cdot \Delta Ir) ; \quad v \in \{1, \dots, Nv\} \quad (15)$$

$$IrSq_{n,n',t} \geq (v \cdot \Delta Ir)^2 - (2v - 1) \cdot \Delta Ir \cdot (Ir_{n,n',v,t} + v \cdot \Delta Ir) ; \quad v \in \{1, \dots, Nv\} \quad (16)$$

$$IiSq_{n,n',t} \geq (v \cdot \Delta Ii)^2 + (2v - 1) \cdot \Delta Ii \cdot (Ii_{n,n',v,t} - v \cdot \Delta Ii) ; \quad v \in \{1, \dots, Nv\} \quad (17)$$

$$IiSq_{n,n',t} \geq (v \cdot \Delta Ii)^2 - (2v - 1) \cdot \Delta Ii \cdot (Ii_{n,n',v,t} + v \cdot \Delta Ii) ; \quad v \in \{1, \dots, Nv\} \quad (18)$$

$$\Delta Ir = \frac{\bar{Ir}_{n,n'}}{Nv} , \quad \Delta Ii = \frac{\bar{Ii}_{n,n'}}{Nv} \quad (19)$$

$$IrSq_{n,n',t} + IiSq_{n,n',t} \leq \bar{I}_{n,n'}^2 \quad (20)$$

299

300 It is worth noting that this approximation is always more than or equal to the exact square, i.e.
 301 $IrSq \geq |Ir|^2$ and $IiSq \geq |Ii|^2$, making current magnitude and network losses larger than the exact
 302 values, resulting in a conservative solution.

Figure 2 Piecewise linear approximation of current magnitude squared

3.7 Bus Voltage Constraints

Bus voltage magnitudes must remain within acceptable minimum and maximum thresholds, $\underline{V}$ and $\bar{V}$, or equivalently between arcs e and b-c shown in Figure 3. Such constraints, however, will be nonlinear when voltages are calculated in the Cartesian coordinates. To model these constraints in a linear approach, we enhanced an approach originally proposed in [38] by replacing the proposed less binding approximation with a more binding approximation (more conservative). Authors in [38] proposed to approximate the exact area (defined by edge a, arc b-c, edge d, and arc e) by the polyhedral area a-f-g-d-h, using (21)-(24). In these equations, $\underline{\theta}$ and $\bar{\theta}$ are the minimum and maximum expected angles for bus voltages.

$$Vi_{n,t} \leq \frac{\sin \bar{\theta} - \sin \underline{\theta}}{\cos \bar{\theta} - \cos \underline{\theta}} (Vr_{n,t} - \underline{V} \cdot \cos \underline{\theta}) + \underline{V} \cdot \sin \underline{\theta} \quad (21)$$

$$Vi_{n,t} \leq \frac{\sin \bar{\theta}}{\cos \bar{\theta} - 1} (Vr_{n,t} - \bar{V}) \quad (22)$$

$$Vi_{n,t} \leq \frac{-\sin \underline{\theta}}{\cos \underline{\theta} - 1} (Vr_{n,t} - \underline{V}) \quad (23)$$

$$Vr_{n,t} \cdot \tan \underline{\theta} \leq Vi_{n,t} \leq Vr_{n,t} \cdot \tan \bar{\theta} \quad (24)$$

This approximation is conservative on the upper bound, and less binding on the lower bound of the voltage. That is because edges f and g are stricter than arcs b and c, but edge h is relaxer than arc e. Since under-voltage problems are more common in distribution networks than over-voltage problems, the less binding constraint on the lower bound may result in microgrid designs and DER placements that lead to under-voltage problems. In our formulation we alleviated this concern by substituting the less binding edge h with the more binding edge h', through replacing $\underline{V}$ with $\underline{V}' = \underline{V} \cdot \sec\left(\frac{\bar{\theta} - \underline{\theta}}{2}\right)$, and rewriting (21) as (25).

$$Vi_{n,t} \leq \frac{\sin \bar{\theta} - \sin \underline{\theta}}{\cos \bar{\theta} - \cos \underline{\theta}} \left(Vr_{n,t} - \underline{V} \cdot \sec \left(\frac{\bar{\theta} - \underline{\theta}}{2} \right) \cdot \cos \underline{\theta} \right) + \underline{V} \cdot \sec \left(\frac{\bar{\theta} - \underline{\theta}}{2} \right) \cdot \sin \underline{\theta} \quad (25)$$

Figure 3 Conservative linear approximation of bus voltage magnitude constraints

3.8 Heating Balance

Equation (26) shows the heat balance at each node, accounting for heating loads and resources, heating needs of absorption chilling ($\frac{1}{COPa} \cdot Gen_{n,j=AC,t}$), heat recovered from CHP units, charging/discharging of heat storage technologies, and heat transfer between nodes (with linear approximation of network losses [28]) through the piping network. Equation (27) enforces the pipe capacities.

$$\begin{aligned} Ld_{n,u=HT,t} - LdCur_{n,u=HT,t} \\ + (1/COPa) \cdot Gen_{n,j=AC,t} &= \sum_{j \in \{ST,BL\}} Gen_{n,j,t} \\ &+ \sum_{g \in \{ICE,MT\}} \alpha_g \cdot Gen_{n,g,t} \\ &- \frac{1}{SCEff_{s=HS}} \cdot SIn_{n,s=HS,t} + SDEff_{s=HS} \cdot SOut_{n,s=HS,t} \\ &- \sum_{n'} HtTr_{n,n',t} + \sum_{n'} (1 - \gamma_{n,n'}) \cdot HtTr_{n',n,t} \end{aligned} \quad (26)$$

$$0 \leq HtTr_{n,n',t} \leq \overline{HtTr}_{n,n'} \quad (27)$$

3.9 Cooling Balance

Equation (28) shows that the cooling load at each node can be met by a combination of electric and absorption chilling and energy from cold storage technology.

$$Ld_{n,u=CL,t} - LdCur_{n,u=CL,t} = \sum_{c \in \{AC, EC\}} Gen_{n,c,t} + SDEff_{s=CS} \cdot SOut_{n,s=CS,t} - \frac{1}{SCEff_{s=CS}} \cdot SIn_{n,s=CS,t} \quad (28)$$

3.10 Storage Constraints

Equation (29) tracks the state of charge (SOC) for electrical, heat, and cold storage technologies, and considers self-discharge. Equation (30) keeps the SOC within its limits and (31) sets rate limits on charging and discharging.

$$SOC_{n,s,t} = (1 - \phi_s) \cdot SOC_{n,s,t-1} + SIn_{n,s,t} - SOut_{n,s,t} \quad (29)$$

$$\underline{SOC}_s \leq SOut_{n,s,t} \leq \overline{SOC}_s \quad (30)$$

$$SIn_{n,s,t} \leq Cap_{n,s} \cdot \overline{SCRt}_s, \quad SOut_{n,s,t} \leq Cap_{n,s} \cdot \overline{SDRt}_s \quad (31)$$

3.11 Generation Constraints

Equations (32)-(34) ensure that the dispatch of each technology does not exceed its maximum capacity or potential. Equation (32) limits the generation of PV and solar-thermal technologies at each time based on the available solar energy at the time. Equations (33)-(35) relate the operating power and capacity for continuous and discrete technologies. The M in (34) denotes a very large number.

$$Gen_{n,c,t} \leq Cap_{n,c} \cdot \frac{SolEff_{c,t}}{ScPkEff_c} \cdot Solar_t; \quad c \in \{PV, ST\} \quad (32)$$

$$Gen_{n,g,t} \leq inv_{n,g} \cdot \overline{DERP}_g \quad (33)$$

$$Cap_{n,k} \leq pur_{n,k} \cdot M \quad (34)$$

$$Gen_{n,c,t} \leq Cap_{n,c} \quad (35)$$

3.12 Import and Export Constraints

Equations (36)-(38) prevent simultaneous import and export to/from the grid and also set the maximum allowable export. Note that if a grid connection does not exist, i.e. parameter $grd = 0$, both $UtPur_{n,t}$ and $UtExp_{n,t}$ will be fixed at zero.

$$UtPur_{n,t} \leq psb_{n,t} \cdot grd \cdot M; \quad n = N \quad (36)$$

$$UtExp_{n,t} \leq (1 - psb_{n,t}) \cdot grd \cdot \overline{UtExp}; \quad n = N \quad (37)$$

$$UtPur_{n,t} = 0, \quad UtExp_{n,t} = 0; \quad n \neq N \quad (38)$$

4 Case Study

4.1 Case Setup and Input Data

The arbitrary 12 kV microgrid shown in Figure 4 was used as an example. This microgrid is composed of 5 nodes and 4 buildings. Typical building load profiles were generated based on commercial building databases [39] with annual electrical, heating, and cooling loads listed in Table 2. For the electrical network, a cable with an impedance of $(64 + i1.4) \times 10^{-6}$ pu/m and ampacity of 0.4 pu was arbitrarily considered. For the heating network, pipes with thermal loss coefficient of $\gamma = 4 \times 10^{-5}$ %/m and capacity of 3000 kW-th were considered. Investments in PV, battery, CHP-enabled Internal Combustion Engine (ICE), absorption chiller, gas-fired boiler, and electric chiller were allowed (characteristics in Table 3 and Table 4).

Figure 4 Electrical and thermal networks for the example 5-node microgrid

Table 2 Building annual electrical, cooling, and heating loads

Node	Annual Electrical Load		Annual Cooling Load		Annual Heating Load	
	Energy (MWh)	Max Power (kW)	Energy (MWh th)	Max Power (kW th)	Energy (MWh th)	Max Power (kW th)
1	1,467	424	450	1,242	1,160	3,282
2	3,181	636	3,204	1,710	4,014	1,196
3	4,059	939	29,295	4,865	10,897	3,379
4	3,341	1,012	4,631	2,403	1,459	4,779
Aggregate	12,048	2,318	37,575	9,743	17,530	12,079

Table 3 Discrete technology option characteristics

	Capacity (kW)	Lifetime (years)	Capital Cost (\$/kW)	Efficiency (%)	Heat Recovery (kW/kW)
ICE-1	1,000	20	4,969	0.368	1.019
ICE-2	2,500	20	4,223	0.404	0.786
ICE-3	5,000	20	3,074	0.416	0.797

360

Table 4 Continuous technology option characteristics

Technology	Fixed Cost (\$)	Variable Cost (\$/kW or \$/kWh)	Lifetime (years)
Battery	500	500	5
PV	2,500	2,500	30
Gas Boiler	6,000	45	10
Electric Chiller	2,300	230	10
Absorption Chiller	250	250	20

361

362 Two cases were studied:

- 363 • *Case I (single-node)*: Building loads were aggregated and electrical and thermal networks were
364 not considered, resulting in a single-node aggregate approach. The DER portfolio and sizes (at
365 the microgrid level) were obtained using the aggregate approach.
- 366 • *Case II (multi-node)*: The multi-node optimization formulation presented in the paper was used
367 and the electrical and thermal networks introduced above were considered. The optimal
368 technology portfolio, DER places, and DER sizes were determined.

369 The results of the two case studies are used to explore how investment options can be different
370 between single-node and multi-node modeling for the same design problem, and hence, demonstrate
371 the importance of the multi-node modeling (with the ability for optimal DER placement) for multi-
372 energy microgrids. To achieve reliable solutions, the optimization precision (stopping criterion) was set
373 to 0.05% in these studies.

374 4.2 Optimal Technology Portfolio and Placement

375 The case study results are reported in Figure 5, Table 5, and Table 6. Figure 5 shows the optimal capacity
376 and placement of various technologies. For each of the two cases, Figure 5 shows the optimal DER and
377 HVAC technology portfolio and capacities. In the single-node approach in case I, technology capacities
378 for nodes 1-5 are not applicable and only the aggregate capacities are relevant. On the contrary in the
379 multi-node study of case II, technology capacities are optimally determined for each node (building). In
380 case II, the solution does not include any investment in node 5, and hence, node 5 is not shown in this
381 figure. The percentages shown on the bars compare the summation of nodal capacities in case II with
382 the aggregate capacity in case I. As an example, it can be seen that a 1,330 kW absorption chiller is
383 installed in case I for the microgrid. In case II, four absorption chillers with 262, 246, 457, and 497 kW
384 capacities are installed at nodes 1-4, respectively. These numbers add up to a total of 1,462 kW, which is
385 10% more than the 1,330 kW capacity from case I.

386 Table 5 shows the annual investment and operation costs for the two cases, where total annual cost is
387 the optimization objective. The percentages for case II costs refer to case I. Table 6 shows the capacity
388 factor for the operation of various technologies in case I and case II. The capacity factors are used to
389 draw some conclusions in the following paragraphs.

Figure 5 Case study results – optimal technology portfolio, placement, and sizes

Table 5 Case study results – annual investment and operation costs

Case No	Annualized Investment Cost (k\$)	Annual Operation Cost (k\$)	Total Annual Cost (k\$)
Case I (Single-node)	1,055	1,561	2,616
Case II (Multi-node)	1,182 (+12.1%)	1,572 (+0.6%)	2,754 (+5.3%)

394

Table 6 Case study results – operation capacity factors for various technologies

Technology	Case I (Single-node)	Case II (Multi-node)				
	Aggregate	Node 1	Node 2	Node 3	Node 4	Aggregate
CHP	74.5%	-	-	73.2%	-	73.2%
Absorption Chiller	11.9%	2.6%	10.2%	4.9%	8.9%	6.7%
Electric Chiller	53.5%	16.9%	36.4%	70.0%	20.0%	54.2%
Gas Boiler	14.9%	4.3%	34.1%	-	10.2%	11.6%

395

396 By comparing case I and II, we can make several observations:

- 397
- 398
- 399
- 400
- 401
- 402
- 403
- 404
- 405
- 406
- 407
- 408
- 409
- 410
- 411
- 412
- 413
- 414
- 415
- 416
- 417
- 418
- 419
- 420
- 421
- 422
- 423
- 424
- 425
- 426
- 427
- 428
- Not only the aggregate technology capacities are different between the two cases, the technology portfolio is also not the same, as the portfolio in case II (multi-node modeling) includes a battery and the portfolio in case I (single-node modeling) does not. This makes the case for the importance of the proposed multi-node modeling approach as opposed to commonly used single-node aggregate approaches.
 - In both cases a 2,500 kW CHP unit is installed and the aggregate boiler capacity remains almost constant from case I to case II. However, the aggregate capacity of PV, battery, absorption chiller, and electric chiller increases from case I to case II.
 - Although the CHP capacity is the same between the two cases, network constraints in case II limit the generation of the CHP unit. As a consequence, the capacity factor of the CHP unit drops from 74.5% in case I to 73.2% in case II.
 - In case II with the optimal DER placement capability, the CHP unit is installed at node 3 (large hotel), which has the highest electrical/cooling/heating load among the four buildings.
 - Although there is no battery in case I, a 672 kWh battery is installed at node 4 in case II. After node 3 (in which the CHP unit is installed), node 4 has the highest electrical load among the four buildings. In this example, the battery is typically used during morning and afternoon peaks to reduce electricity purchase from the utility during these hours (it will be shown in section 4.3).
 - The absorption cooling becomes less attractive in case II, where network constraints are considered. Instead, the amount of electric cooling increases, followed by a higher overall installed electric chiller capacity in case II. It is worth noting that although the total amount of cooling met by absorption decreases in case II, the installed capacity for absorption chillers increases. This seemingly contradicting result is a reflection of the load aggregation used in case I. Namely, the absorption cooler in the single-node formulation is sized based on the maximum overall (aggregated) absorption cooling load (in kW), which is not necessarily the same as individually sizing absorption chillers based on the loads in each of the nodes. Hence, the total absorption chiller size of all 4 nodes in case II exceeds the installed capacity in case I, even though the effective amount of cooling met through absorption chillers is lower. This is confirmed by analyzing the capacity factor for the absorption coolers in the system, which decreases from 11.9% in case I to 6.7% in case II.
 - As a result of the lower use of absorption chillers, the total heating load, which includes heat used to drive these chillers, is smaller in case II than in case I. However, the same observation is made regarding total installed capacity, as the boiler at each node is sized based on the

maximum heating load at that node, and this results in a total capacity which exceeds the maximum of the aggregate load in the single-node formulation, even though the boilers are used less often. Once again, this is confirmed by analyzing the aggregate capacity factor of boilers, which decreases from 14.9% in case I to 11.6% in case II.

- The investment cost in case II is 12.1% higher due to installing more DERs in the microgrid.
- The 0.6% increase in the annual operation cost is the aggregate outcome of several conflicting changes from case I to case II, including more electricity purchase from the utility, more onsite PV generation, and less fuel consumption. Also in contrast with case I, the network electrical and thermal losses are modeled in case II.
- The total annual investment and operation cost in this example increases by 5.3% when electrical and thermal network constraints are taken into account. It indicates that single-node aggregate approaches may under-estimate investment capacities and annual costs. We have conducted further studies that showed the under-estimation gap increases as the network weakens (higher line impedances and lower line ampacities). Another problem with aggregate approaches, as discussed earlier in the paper, is that they are inherently unable to perform optimal DER placement.

4.3 Optimal Electrical, Cooling, and Heating Dispatch

Figure 6 shows the optimal electrical dispatch for nodes 1-5 in case II during a typical week day in August (month and day-type arbitrarily chosen). For each node the demand is composed of the node electrical load, consumption of the electric chiller at the node, and the electrical power being exported to other nodes. The supply includes PV generation at the node, ICE generation at the node, discharge of the battery at the node, electricity purchased from the grid at the node, and electrical power being imported from other nodes. In node 4 when the supply exceeds the demand, excess energy is stored in the battery. The battery state of charge can be seen on the second axis.

Node 5 is the point of common coupling to the utility grid and does not have any loads. It can be observed that the microgrid only purchases electricity from the grid during morning and afternoon load peaks, i.e. 7-10am and 7-9pm. It can also be observed that the electricity purchase from the grid has an almost flat profile during these hours in order to minimize incurred demand charges. As explained in section 3.5, an approximation of the entire microgrid power loss is modeled at the slack bus in our formulation (bus 5 in this example). The excess supply power seen in this node is to compensate network losses.

It can be observed that the CHP unit in node 3 runs continuously and exports its excess power to other nodes. Nodes 1, 2, and 4 are importer nodes and never have extra supply to export. The dispatch at node 4 shows that the battery is used during morning and afternoon load peak hours. The battery helps to reduce electricity purchase from the grid and also to keep a flat purchase profile during these hours.

Figure 7 shows the optimal heating dispatch for nodes 1-4 in case II for the same month and day-type. Node 5 is not shown since it does not have any heating loads or resources. The demand at each node is composed of water/space heating load, heating load of absorption cooling, and heat export to other nodes. The node supply entails heat provided by the boiler at the node, heat recovered from CHP at the

node, and imported heat from other microgrid nodes. It can be observed that node 3 is a heat exporter node and transfers its excess recovered heat to other nodes. Nodes 1 and 2 are heat importers and use the imported heat along with their boilers to meet their demands. Node 4 imports heat from node 3 from 9am to 5pm and exports to node 3 before 9am and after 5pm.

Figure 8 shows the optimal cooling dispatch for nodes 1-4 in case II for the same month and day-type. It can be seen that the cooling load at each node is met by a combination of electric and absorption cooling at the node. Since node 3 has a CHP unit, one may expect the cooling load in this node to be met mostly by absorption cooling. However, the dispatch in this figure shows that this node has the lowest absorption to electric cooling ratio among the four nodes. That is because the electrical network capacity is fairly limited, while the piping network has a high capacity. As a result, the electrical generation of the CHP unit is used locally to supply the electrical loads (including electric chiller) and most of the recovered heat is exported to other nodes for their heating and absorption cooling loads.

Figure 9 shows the optimal electrical, heating, and cooling dispatch for the microgrid in case I for the same month and day-type, i.e. a typical weekday in August. The aggregate modeling is not able to capture the microgrid's internal energy transfer. It is also unable to determine the dispatch at the node level. To further demonstrate the optimal dispatch differences between single-node and multi-node modeling, Figure 10 compares the (aggregate) optimal dispatch between case I (single node) and case II (multi-node). In case I, system loads are met by PV and CHP technologies. On the contrary in case II loads are served by PV, CHP, utility electricity, and battery. It can be observed that the electric chiller loads are also different between the two cases, which is because of the different absorption and electric chiller sizes.

Figure 6 Case study results – optimal electricity dispatch in case II (a typical weekday in August)

Figure 7 Case study results – optimal heating dispatch in case II (a typical weekday in August)

Figure 8 Case study results – optimal cooling dispatch in case II (a typical weekday in August)

506

507

508

509

Figure 9 Case study results – optimal electricity, heating, and cooling dispatch in case I (a typical weekday in August)

Figure 10 Case study results – comparison of aggregate electricity dispatch between case I and II (a typical weekday in August)

4.4 Accuracy of the Approximate Power Flow Solution

In our formulation, a linear approximation of power flow equations is used. Figure 11 shows the histogram and cumulative distribution function (CDF) for the errors in bus voltage magnitudes in case II. To generate this plot, the exact power flow solution (Newton-Raphson method) was calculated for the network at each time step using the optimal dispatch (output from the optimization), and the exact power flow solution was compared with the approximation (from within the optimization) for all the data points. It can be observed that the errors are very small and 97% of the voltage data points have an error less than 0.25%. Figure 12 shows the voltage variation (over a year) at each node for both exact and approximate power flow solutions. It can be observed that the ranges are very close. Also, the voltage never drops below the minimum acceptable threshold of 0.9pu.

Figure 11 Case study results – accuracy of the approximate power flow solution

Figure 12 Case study results – voltage magnitude variations at each node

4.5 Verification of the “Approximate Power Flow Existence Condition”

As discussed in section 3.5, the network needs to meet the “approximate power flow existence condition” for the power flow equations to be valid. It was explained that this condition can be verified using two methods:

- Method one, post-optimization: The $\|s_t\|$ calculated from the optimization results ranges between 0.32506 and 1.4087. All of the $\|s_t\|$ in this range satisfy the “approximate power flow existence condition”.
- Method two, pre-optimization: For the example microgrid, the sufficient condition of (9) for the pre-optimization verification of the power flow model holds true, since

$$\sqrt{\sum_{n \neq N} \left(\sum_{n'} \bar{s}_{n,n'} \right)^2} = \sqrt{4 \times (0.4 + 0.4)^2} = 1.6 \leq \frac{1}{4 \cdot \|Z\|_*} \cdot V_0^2 = \frac{1}{4 \times 0.13} = 1.92.$$

5 Conclusions and Future Work

This paper presented a mixed-integer linear programming model for optimal microgrid design, including optimal technology portfolio, placement, and dispatch, for multi-energy microgrids, i.e. microgrids with electricity, heating, and cooling loads and resources. To optimally place DERs in the microgrid, our optimization formulation includes integer linear models for electricity and heat transfer networks, as well as their physical and operational constraints.

To illustrate how the developed optimization model works, we conducted a case study in which we solved the optimal microgrid design problem for an example microgrid using both a single-node aggregate approach (and hence without DER placement) and our proposed multi-node approach (with DER placement). The results indicated that aggregate approaches are inherently incapable of DER placement in the microgrid. Moreover, they may result in non-optimal technology portfolio and underestimation of DER capacities, since they cannot capture the internal energy transfer within the microgrid and the limitations of the electrical/thermal networks. For the example microgrid studied, we also compared our approximate power flow solution with the exact power flow solution and observed very small errors in bus voltage magnitudes.

Further research work will focus on modeling of larger microgrids with more nodes and studying its impact on the solution time. Integrating alternative linear power flow models will also be pursued. Furthermore, research will be carried out on the inclusion of network design (cable connections and types), as well as N-1 security constraints, and evaluating their impact on the technology portfolio and investment cost.

6 Acknowledgment

The authors gratefully thank Dan T. Ton, the Smart Grid R&D Program Manager at the US Department of Energy, for his continuous support of the microgrid design tools at LBNL.

7 References

- [1] "About the Initiative," New York State Department of Public Service, 2015. [Online]. Available: www.dps.ny.gov/REV/.
- [2] C. Marnay, F. J. Robio, and A. S. Siddiqui, "Shape of the microgrid," in *Proc. 2001 IEEE Power Engineering Society Winter Meeting*, pp. 150-153, 2001.
- [3] M. Stadler, G. Cardoso, S. Mashayekh, T. Forget, N. DeForest, A. Agarwal, and A. Schönbein, "Value streams in microgrids: A literature review," *Applied Energy*, vol. 162, pp. 980-989, 2016.
- [4] C. Brandoni and M. Renzi, "Optimal sizing of hybrid solar micro-CHP systems for the household sector," *Applied Thermal Engineering*, vol. 75, pp. 896-907, 2015.
- [5] M. Motevasel, A. R. Seifi, and T. Niknam, "Multi-objective energy management of CHP (combined heat and power)-based micro-grid," *Energy*, vol. 51, pp. 123-136, 2013.
- [6] P. Mancarella, "MES (multi-energy systems): An overview of concepts and evaluation models," *Energy*, vol. 65, pp. 1-17, 2/1/ 2014.
- [7] D. Connolly, H. Lund, B. V. Mathiesen, and M. Leahy, "A review of computer tools for analysing the integration of renewable energy into various energy systems," *Applied Energy*, vol. 87, pp. 1059-1082, 2010.

- 575 [8] G. Mendes, C. Ioakimidis, and P. Ferrão, "On the planning and analysis of Integrated Community
576 Energy Systems: A review and survey of available tools," *Renewable and Sustainable Energy
577 Reviews*, vol. 15, pp. 4836-4854, 2011.
- 578 [9] Z. Huang, H. Yu, Z. Peng, and M. Zhao, "Methods and tools for community energy planning: A
579 review," *Renewable and Sustainable Energy Reviews*, vol. 42, pp. 1335-1348, 2015.
- 580 [10] C. Gamarra and J. M. Guerrero, "Computational optimization techniques applied to microgrids
581 planning: A review," *Renewable and Sustainable Energy Reviews*, vol. 48, pp. 413-424, 2015.
- 582 [11] A. H. Fathima and K. Palanisamy, "Optimization in microgrids with hybrid energy systems – A
583 review," *Renewable and Sustainable Energy Reviews*, vol. 45, pp. 431-446, 5// 2015.
- 584 [12] A. Ahmad Khan, M. Naeem, M. Iqbal, S. Qaisar, and A. Anpalagan, "A compendium of
585 optimization objectives, constraints, tools and algorithms for energy management in
586 microgrids," *Renewable and Sustainable Energy Reviews*, vol. 58, pp. 1664-1683, 5// 2016.
- 587 [13] W.-S. Tan, M. Y. Hassan, M. S. Majid, and H. Abdul Rahman, "Optimal distributed renewable
588 generation planning: A review of different approaches," *Renewable and Sustainable Energy
589 Reviews*, vol. 18, pp. 626-645, 2013.
- 590 [14] D. Singh, D. Singh, and K. S. Verma, "Multiobjective Optimization for DG Planning With Load
591 Models," *IEEE Transactions on Power Systems*, vol. 24, pp. 427-436, 2009.
- 592 [15] C. L. T. Borges and D. M. Falcão, "Optimal distributed generation allocation for reliability, losses,
593 and voltage improvement," *International Journal of Electrical Power & Energy Systems*, vol. 28,
594 pp. 413-420, 2006.
- 595 [16] B. Kroposki, P. K. Sen, and K. Malmedal, "Optimum Sizing and Placement of Distributed and
596 Renewable Energy Sources in Electric Power Distribution Systems," *IEEE Transactions on
597 Industry Applications*, vol. 49, pp. 2741-2752, 2013.
- 598 [17] J.-H. Teng, Y.-H. Liu, C.-Y. Chen, and C.-F. Chen, "Value-based distributed generator placements
599 for service quality improvements," *International Journal of Electrical Power & Energy Systems*,
600 vol. 29, pp. 268-274, 2007.
- 601 [18] W. Zhaoyu, C. Bokan, W. Jianhui, K. Jinho, and M. M. Begovic, "Robust Optimization Based
602 Optimal DG Placement in Microgrids," *IEEE Transactions on Smart Grid*, vol. 5, pp. 2173-2182,
603 2014.
- 604 [19] D. Buoro, M. Casisi, A. De Nardi, P. Pinamonti, and M. Reini, "Multicriteria optimization of a
605 distributed energy supply system for an industrial area," *Energy*, vol. 58, pp. 128-137, 2013.
- 606 [20] D. Buoro, P. Pinamonti, and M. Reini, "Optimization of a Distributed Cogeneration System with
607 solar district heating," *Applied Energy*, vol. 124, pp. 298-308, 2014.
- 608 [21] T. Wakui, T. Kinoshita, and R. Yokoyama, "A mixed-integer linear programming approach for
609 cogeneration-based residential energy supply networks with power and heat interchanges,"
610 *Energy*, vol. 68, pp. 29-46, 2014.
- 611 [22] E. D. Mehleri, H. Sarimveis, N. C. Markatos, and L. G. Papageorgiou, "A mathematical
612 programming approach for optimal design of distributed energy systems at the neighbourhood
613 level," *Energy*, vol. 44, pp. 96-104, 2012.
- 614 [23] S. Bracco, G. Dentici, and S. Siri, "Economic and environmental optimization model for the
615 design and the operation of a combined heat and power distributed generation system in an
616 urban area," *Energy*, vol. 55, pp. 1014-1024, 2013.
- 617 [24] C. Weber and N. Shah, "Optimisation based design of a district energy system for an eco-town in
618 the United Kingdom," *Energy*, vol. 36, pp. 1292-1308, 2011.
- 619 [25] A. Omu, R. Choudhary, and A. Boies, "Distributed energy resource system optimisation using
620 mixed integer linear programming," *Energy Policy*, vol. 61, pp. 249-266, 2013.

- [26] J. Keirstead, N. Samsatli, N. Shah, and C. Weber, "The impact of CHP (combined heat and power) planning restrictions on the efficiency of urban energy systems," *Energy*, vol. 41, pp. 93-103, 2012.
- [27] E. D. Mehleri, H. Sarimveis, N. C. Markatos, and L. G. Papageorgiou, "Optimal design and operation of distributed energy systems: Application to Greek residential sector," *Renewable Energy*, vol. 51, pp. 331-342, 2013.
- [28] J. Söderman and F. Pettersson, "Structural and operational optimisation of distributed energy systems," *Applied Thermal Engineering*, vol. 26, pp. 1400-1408, 2006.
- [29] Y. Yang, S. Zhang, and Y. Xiao, "Optimal design of distributed energy resource systems coupled with energy distribution networks," *Energy*, vol. 85, pp. 433-448, 6/1/ 2015.
- [30] B. Morvaj, R. Evins, and J. Carmeliet, "Optimization framework for distributed energy systems with integrated electrical grid constraints," *Applied Energy*, vol. 171, pp. 296-313, 6/1/ 2016.
- [31] A. K. Basu, A. Bhattacharya, S. Chowdhury, and S. P. Chowdhury, "Planned Scheduling for Economic Power Sharing in a CHP-Based Micro-Grid," *IEEE Transactions on Power Systems*, vol. 27, pp. 30-38, 2012.
- [32] G. Cardoso, M. Stadler, M. C. Bozchalui, R. Sharma, C. Marnay, A. Barbosa-Póvoa, and P. Ferrão, "Optimal investment and scheduling of distributed energy resources with uncertainty in electric vehicle driving schedules," *Energy*, vol. 64, pp. 17-30, 2014.
- [33] "Distributed Energy Resources Web Optimization Service (WebOpt)," Grid Integration Group, Lawrence Berkeley National Lab, 2015. [Online]. Available: <https://building-microgrid.lbl.gov/projects/distributed-energy-resources-web>.
- [34] O. Bailey, C. Creighton, R. Firestone, C. Marnay, and M. Stadler, "Distributed energy resources in practice: A case study analysis and validation of LBNL's customer adoption model," Lawrence Berkeley National Laboratory, LBNL-52753, 2003. [Online]. Available: <http://eetd.lbl.gov/sites/all/files/publications/report-lbnl-52753.pdf>
- [35] A. Mammoli, M. Stadler, N. DeForest, H. Barsun, R. Burnett, and C. Marnay, "Software-as-a-Service Optimised Scheduling of a Solar-Assisted HVAC System with Thermal Storage," in *Proc. 2013 International Conference on Microgeneration and Related Technologies*, 2013.
- [36] C. B. Jones, M. Robinson, H. Barsun, L. Ghanbari, A. Mammoli, S. Mashayekh, W. Feng, and C. Marnay, "Software-as-a-Service Optimal Scheduling of New Mexico Buildings," in *Proc. 2015 ECEEE 2015 Summer Study on Energy Efficiency*, June, 2015.
- [37] S. Bolognani and S. Zampieri, "On the Existence and Linear Approximation of the Power Flow Solution in Power Distribution Networks," *IEEE Transactions on Power Systems*, vol. PP, pp. 1-10, 2015.
- [38] J. F. Franco, M. J. Rider, M. Lavorato, and R. Romero, "A mixed-integer LP model for the reconfiguration of radial electric distribution systems considering distributed generation," *Electric Power Systems Research*, vol. 97, pp. 51-60, 2013.
- [39] "Commercial reference buildings," Department of Energy, [Online]. Available: <http://energy.gov/eere/buildings/commercial-reference-buildings>.