Impact of Climate Change Heating and Cooling Energy Use in Buildings in the United States

Haojie Wang¹ and Qingyan Chen^{2,1*}

¹School of Mechanical Engineering, Purdue University, West Lafayette, IN 47907, USA

²School of Environmental Science and Engineering, Tianjin University, Tianjin 300072, China

*Tel. (765)496-7562, Fax (765)494-0539, Email: yanchen@purdue.edu

Abstract

Global warming has drawn great attention in recent years because of its large impact on many aspects of the environment and human activities in buildings. One area directly affected by climate change is the energy consumption for heating and cooling. To quantify the impact, this study used the HadCM3 Global Circulation Model (GCM) to generate weather data for future typical meteorological years, such as 2020, 2050, and 2080, for 15 cities in the U.S. based on three CO₂ emission scenarios. The method was validated by comparing the projected TMY3 data using HadCM3 with the actual TMY3 data. By morphing method, the weather data was downscaled to hourly data for use in building energy simulations by EnergyPlus. Two types of residential buildings and seven types of commercial buildings were simulated for each of the 15 cities. This paper is the first to systematically study the climate change impact on various types of residential and commercial buildings in all 7 climate zones in the U.S. through EnergyPlus simulations and provide weighted averaged results for national-wide building stock. We also identified geographical dependency of the impact of climate change on future energy uses. There would be a net increase in source energy consumption by the 2080s for climate zones 1-4 and net decrease in climate zones 6-7 **based on the HadCM3 weather projection**. Furthermore, this paper investigated natural ventilation performance in San Francisco, San Diego, and Seattle with improved natural ventilation model. We found that by the 2080s passive cooling would not be suitable for San Diego because of global warming, but it would still be acceptable for San Francisco and Seattle.

Keywords: climate change; building energy use; global warming; EnergyPlus; natural ventilation

1. Introduction

Climate change and global warming have been of major concern to the public because of the potential threat to the ecosystem and living environment. The Intergovernmental Panel on Climate Change (IPCC) has projected that the annual temperature increase from the 1960s to the 2100s will be in the range of 1 to 7 K under various CO₂ emission scenarios [1]. In addition to temperature change, humidity, wind, and solar radiation are also likely to change over the years because of higher CO₂ emissions [2]. Climate change will have a large impact on building energy use for heating and cooling because of the change in outdoor conditions [3, 4]. In 2010, building energy consumption accounted for 41% of the total prime energy use in the U.S., and about 50% of the building energy consumption was for space heating and cooling [5]. Energy consumption levels for cooling and heating are expected to increase and decrease, respectively, as a result of global warming [6]. However, the impact of climate change on heating and cooling energy use in different locations will vary because of their different climates [3, 7]. A detailed analysis of heating and cooling energy use in the future is needed to better understand the impact of climate change on building energy consumption.

A reasonable prediction of the future climate is the first requirement for an energy analysis of buildings. The most comprehensive models for future climate prediction are Atmosphere-Ocean Global Circulation Models (AOGCMs) [1]. Among the various AOGCMs, HadCM3 has been widely used for predicting future climates [8-10] because of its higher ocean resolution, which enables it to generate reasonable predictions without the need for artificial flux adjustment [11].

In early studies, the degree day method was widely used with future weather data to determine the impact of climate change on building energy consumption [4, 12]. Degree day analysis uses the balance point temperature of a building, that at which the building does not require either cooling or heating. The choice of balance point temperature can be different for each region and each type of building [13]. The Heating Degree Days (HDDs) and Cooling Degree Days (CDDs) are calculated hourly over a year as

$$\text{HDD} = \sum_{i=1}^{365} \sum_{j=1}^{24} (T_b - T_o)^+ / 24 \quad (1)$$

$$\text{CDD} = \sum_{i=1}^{365} \sum_{j=1}^{24} (T_o - T_b)^+ / 24 \quad (2)$$

where T_b is the balance point temperature and is usually assumed to be 18.3 °C (65 °F) for the sake of simplicity [13]. T_o is the outdoor daily temperature. The plus sign means that only positive values will be used, and all negative values are treated as zero. This method can provide a quick estimate of the impact of climate change on buildings. However, since solar radiation, humidity, and building characteristics such as thermal mass are not considered in degree day analysis, studies have often found that this method would lead to large deviations as compared to energy simulations [14]. Therefore, hour-by-hour energy simulation is better for studying the impact of climate change on heating and cooling energy consumption in buildings.

Furthermore, the impact of climate change will vary greatly according to geographical region and building types [3, 6]. Many residential buildings in coastal areas and mild climate zones do not have air-conditioning systems and depend solely on natural ventilation for cooling [18]. These differences among HVAC systems will lead to variations in the impact of climate change. Table 1 lists past literature that studied the impact of climate change on building energy consumption. It shows that most of studies are regional based and only focus on a few types of buildings, thus could not predict the general impact of climate change on the whole building stock. Furthermore, the results from each author varied greatly and are not comparable because the types of the building and climate characteristics were not systematically classified.

Therefore, to systematically study the impact of climate change on the whole building stock in the U.S., this paper reports our findings of the change in cooling energy use in buildings in 15 different U.S. cities located in seven climate zones as described in ASHRAE 90.1 [25] by 2080s. The energy simulations in each city included two types of residential buildings and seven types of commercial buildings. This study also evaluated natural ventilation performance in San Francisco, San Diego, and Seattle, where it is widely used in residential buildings. The study addresses the impact of climate change across the nation on heating and cooling energy consumption.

2. Methodology

2.1. Future weather data

This study used the HadCM3 model to project future climate change for three different CO₂ emission scenarios (A1F1: high emission; A2: medium emission, and B1: low emission) [1]. This model contains coupled the atmosphere model HadAM3, with a horizontal resolution of 2.5° latitude by 3.75° longitude, and oceanic model HadOM3 with horizontal resolution of 1.25° by 1.25°. The two components exchanged information daily and would conserve heat and water mass flux but since momentum fluxes are interpolated between the atmosphere and ocean grids, it is not conserved precisely. Nevertheless, Johns et al. [10] have shown this imbalance did not affect the results significantly. HadCM3 provides the monthly change in dry-bulb temperature, diurnal temperature variation, relative humidity, wind speed, and solar radiation, which have a major impact on the building heating and cooling load and can be found on IPCC website for three emission scenarios (http://www.ipcc-data.org/sres/hadcm3_download.html). Since the grid point of HadCM3 might not coincide exactly at the locations studied in this paper, we use linear interpolation from the four closest grid points. Moreover, another problem with HadCM3 model and other AOGCMs is that they only provide monthly data, which is insufficient for hourly energy simulation. We therefore used a morphing method to down-scale the monthly changes to hourly changes and then applied the changes to the current weather data [15-17]. The general formula for calculating future hourly weather parameter x includes a stretching factor and shifting to the original weather parameter x_0 as

$$x = x_0 + \Delta x_m + a_m(x_0 - \langle x_0 \rangle_m) \quad (3)$$

where x_0 is the current hourly weather data, Δx_m the monthly mean change obtained from HadCM3, a_m the stretching factor, and $\langle x_0 \rangle_m$ the monthly mean of the current weather data. A simple verification of the monthly mean of from Eq. (3) (taking monthly mean value, denoted by $\langle \rangle_m$, on each side of Eq.3, yields $\langle x \rangle_m = \langle x_0 \rangle_m + \Delta x_m$) showed that this method conserves the original monthly mean change obtained from the HadCM3 model.

For the future hourly dry-bulb temperature, the stretching factor a_m in Eq. (3) is calculated as

$$a_m = \frac{\Delta TMAX_m - \Delta TMIN_m}{\langle T_{db0,max} \rangle_m - \langle T_{db0,min} \rangle_m} \quad (4)$$

where $\Delta TMAX_m$ and $\Delta TMIN_m$ are the monthly mean changes in diurnal temperature in the future, which were obtained from the HadCM3 model, and $\langle T_{db0,max} \rangle_m$ and $\langle T_{db0,min} \rangle_m$ are the monthly mean changes in diurnal temperature under current weather conditions. For humidity and wind speed, the data provided in HadCM3 are changes in percentage, and thus only the stretching factor is applied as

$$x = (1 + \Delta x_m / 100) x_0 \quad (5)$$

where x is the future wind speed or relative humidity, Δx_m the monthly mean change (in percentage) obtained from the HadCM3 data, and x_0 the current weather data. For solar radiation, only the stretching factor is used because the shifting would add solar radiation at night, which is unrealistic. The solar irradiance on horizontal surface I_h is calculated as

$$I_h = (1 + \Delta I_{h,m} / \langle I_{h,0} \rangle_m) I_{h,0} \quad (6)$$

where I_h is the future hourly solar irradiance, $\Delta I_{h,m}$ the monthly mean change in solar irradiance, and $I_{h,0}$ the current hourly solar irradiance.

This study used six typical meteorological year (TMY) data sets, including three historical TMY data sets: TMY (data from 1948-1980), TMY2 (1961-1990), and TMY3 (1991-2005), which were obtained from the National Renewable Energy Laboratory. (For the sake of simplicity, the figures in this paper use the median year during the period when the weather data was collected to denote TMY, TMY2, and TMY3, i.e. TMY is denoted as 1964, TMY2 as 1976, and TMY3 as 1998.) The future TMY data for the 2020s, the 2050s, and the 2080s was generated by Eqs. (4)-(6), and we then applied the hourly changes to TMY3. Table 2 lists the 15 cities investigated in this paper and their corresponding climate zones.

This study also conducted a simple degree day analysis and compared the results with energy simulations. The balance point used in this study was 18.3 °C (65 °F) [13] for all the cities. The heating degree days and cooling degree days were calculated using Eqs. (1) and (2).

2.2. Building model

This study investigated nine types of buildings with the EnergyPlus 8.1 program [26] and the geometry was rendered by Sketchup. In order to determine the impact of climate change on the entire building stock in the U.S., this study weighted the energy intensity for each type of building by the floor area of that type as a percentage of the total floor area in the U.S. building stock. Table 3 lists the types of buildings studied, their total floor areas in the U.S., and important building model information. The total outdoor air ACH is the sum of infiltration and mechanical ventilation based on ASHRAE Standards 62.1 [27] and 62.2 [28]. Figure 1 shows the rendering of the building models used in the EnergyPlus program.

Table 4 shows the building envelope and internal load information for the model. The commercial building models used in this investigation are from Thornton et al. [29] and represent typical commercial buildings in the U.S. The residential building models used are from Mendon et al. [30]. The commercial building envelope insulation is based on ASHRAE 90.1 [25] Table 5.5-1 to 5.5-7; the internal load, including people, lighting, plug load are based on space types from Thornton et al. [29] for commercial buildings and Mendon et al. [30] for residential buildings; the heating/cooling setpoints are set as 21/24 °C with 2.7 °C setback during unoccupied hours. The residential building envelope insulation are designed to meet the minimum requirements set by Table 5.2 in ASHRAE 90.2 [31] for each climate zone. Because many of the residential buildings in San Francisco, San Diego, and Seattle do not have air-conditioning systems [18], this study also investigated scenarios with natural ventilation as the cooling strategy for single-family houses in these three cities by switching the mechanical system module to the natural ventilation module. The ventilation rate for natural ventilation was calculated on the basis of a model developed by Wang and Chen [32] and was implemented into EnergyPlus. The control strategy for natural ventilation was to keep the window open when the outdoor temperature was between 16 to 26°C, which is 2-4°C lower than the 90% acceptable indoor temperature defined by ASHRAE adaptive comfort model [29] which is used to meet the cooling load in the building.

The weighted building heating and cooling energy intensities I for the nine types of buildings were calculated as

$$I = \sum_{i=1}^9 \left(\frac{E_i}{A_{simu,i}} \cdot \frac{A_{total,i}}{A_{total}} \right) \quad (7)$$

where E_i is the energy for cooling or heating for building type i calculated by EnergyPlus, $A_{simu,i}$ the floor area of the building model for building type i in EnergyPlus, $A_{total,i}$ the total floor area in the U.S. building stock for building type i , and A_{total} the total floor area of all types of buildings in the U.S.

3. Results and Discussion

3.1. Weather characteristics

The first step of this study was to generate weather data for the future by using the model proposed in the previous section on the basis of the current TMY3 data. In order to validate the accuracy of HadCM3 model, we first applied this model to TMY2 data to obtain the predicted TMY3 data and compared them with the actual TMY3 data. Figure 2 shows the comparisons of monthly dry-bulb, dew point temperature and global horizontal solar radiation intensity, which are the major inputs in energy simulations. The results showed that for dry-bulb and solar radiation, the prediction is generally within the 10% error, but for humidity, i.e. the dew point temperature, we observed some large deviation near 0 °C. One reason is that the humidity ratio at low temperature is very small, thus even a small absolute deviation will result in large relative deviation. Nevertheless, since humidity only impact the building latent cooling load, which usually occurs at above 12 °C, the deviation at low dew point temperature would not have impact on the building energy prediction.

Figure 3(a) shows the change in annual temperature in the four selected cities between the 1960s to the 2080s under the medium CO₂ emission scenario (A2). The first three weather data points are the actual data for a typical meteorological year. The annual temperature in each weather data set was compared to the 1964 (TMY) data to calculate the temperature change. The results indicate that the temperature change varies greatly with location. By 2080, the changes are in the range of 3-6°C for the four cities, which agrees with the IPCC report [1]. Furthermore, Figure 3(a) shows that the temperature changes more rapidly after 2000. This trend is caused by the

rapid growth in population and the slow rate of technology change as described in the A2 emission scenario [1].

Figure 3(b) compares the future weather data under the three CO₂ emission scenarios for New York City. The annual temperature change from 1964 to 2080 under the high CO₂ emission scenario (A1F1) would be 6°C, while under the low emission scenario (B2) it would be only 3°C. By simulating the three scenarios, we cover a wide range of possible levels of climate change. Even if there were large uncertainties in the HadCM3 model, our energy simulations would account for the potential best- and worst-case scenarios.

3.2. Energy analysis

This section discusses the results of our EnergyPlus simulations. Our study conducted more than 2000 simulations covering 15 cities, nine types of buildings, three historical weather data sets, and three future weather data sets under the three emission scenarios. We assumed that the building stock structure is the same in every city studied in this paper and remain unchanged throughout the simulation period, namely, each type of building would have the same floor area fraction to the total building stock in the U.S. in all the cities studied in this paper. The energy intensity for each city was weighted by the floor area fraction for each type of building as described in Eq. (7).

Figure 4(a) shows the changes in site energy intensity for cooling and heating by the 2080s as compared to the 1960s. Typically, because of global warming, the energy intensity for cooling for all the cities would increase under the three CO₂ emission scenarios, and the energy intensity for heating would decrease. However, as climate characteristics vary from city to city, the magnitude of change also varies. In hot climates, the change in cooling energy intensity will be much larger than that for heating, as seen in Houston, Miami, and San Diego. In cold or very cold climates, the decrease in site energy for heating will largely exceed the increase in site energy for cooling.

In this study, the energy sources were natural gas for heating and electricity for cooling. Since electricity has more exergy than natural gas in one unit of energy, it is unreasonable to compare

the cooling and the heating energy directly. Instead, the site energy should be converted to source energy and used to calculate the net change of energy use for cooling and heating. Deru and Torcellini [34] estimated that the national average site-to-source conversion factors were 3.365 for electricity and 1.092 for natural gas. Site-to-source conversion is largely dependent on the energy source structure in the U.S., and it may become lower for electricity in the future, as the efficiency of power plants improves and renewable energy is more widely used. However, because information about future conditions was not available, we assumed the site-to-source factor to be constant from the 1960s to the 2080s.

After applying the conversion factor and calculating the total source energy for both heating and cooling, we obtained the net change in source energy consumption by the 2080s. Figure 4(b) shows the change in energy intensity for 15 cities by 2080 as compared to 1964 (TMY) weather data under three emission scenarios. Positive values in Figure 4(b) indicate that the source energy use for heating and cooling would increase by the 2080s, while negative values indicate a decrease. The figure shows a net reduction in energy use by heating and cooling sources for cities in cold and very cold climates, i.e. Climate Zones 6 and 7. Some cities in Climate Zone 4, such as Seattle, would have a net decrease under all scenarios; however, other cities in this climate zone, such as Baltimore and New York, would have a net reduction only under the low emission scenario. The cities in Climate Zones 1-3 would have a net increase in source energy intensity under all three emission scenarios by the 2080s.

This study also compared the energy analysis by the simplified degree day method with that by EnergyPlus simulations under the medium emission scenario in Atlanta, Miami, Minneapolis, and San Francisco. For cooling, as shown in Figure 5(a), the degree day method yielded results that were similar to those of the EnergyPlus simulations for Atlanta and Miami, but there was a large discrepancy for San Francisco. In a mild climate such as that of San Francisco, the cooling degree days are much more sensitive to the balance point temperature than in those cities that have a large cooling demand. Because this study selected 18.3 °C (65 °F) as the balance point temperature without regard to building type or climate, it may not accurately represent buildings in San Francisco. Another reason for the deviation is that the absolute value for cooling energy in

San Francisco was small, and thus the relative value would be sensitive to even a very small change.

In the heating analysis, because Miami does not require heating most of the time, it was replaced by Minneapolis. The results obtained by the degree day method match reasonably well with those from the EnergyPlus simulations for cities with a large heating demand, as shown in Figure 5(b). In San Francisco, where a steady increase in cooling demand was observed (Figure 5(a)), the heating demand was found to fluctuate between 1960 and 2000 (Figure 5(b)). This latter trend was captured by both the degree day analysis and the energy simulation. A possible reason for the fluctuation in heating would be erratic weather occurrences such as winter storms and warm winter temperatures during that period of time. For example, California reportedly had several warm winters around the 2000s, which reduced heating demand. A comparison of the two energy analysis methods indicates that there are relatively small differences for buildings in hot or cold climates but a large deviation between the two methods in a mild climate.

Buildings interact with climates primarily through exterior walls, roofs, windows, ventilation systems, and infiltration. Buildings with a higher insulation level, larger core zone ratio, smaller window-to-wall ratio, and lower infiltration and outdoor air supply are more isolated from outdoor conditions and thus would be less affected by climate change. For each building type, Tables 3 and 4 list important parameters that influence the impact of outdoor climate on the buildings.

Figure 6 compares the impact of climate change on cooling energy for different types of buildings in four cities by the 2080s under the medium emission scenario. Hospitals experience the smallest relative change in cooling energy even though hospital has large outdoor air requirement. There are two major reasons for this: 1) hospitals have large building internal load, such as interior equipment, lighting, which remain constant regardless of outdoor climate change, thus the relative change will be small; 2) the hospitals usually have large ratio of core zone to total floor area (85% in this model) and small window-to-wall ratio (16%), which could reduce the envelope loss. Restaurants suffer the most from global warming, primarily because all zones are exposed to the outdoors, as shown in Figure 1, and restaurants have the largest amount of

outdoor air intake (7.14 ACH). Residential buildings such as single-family houses and apartments would have a relatively large increase in cooling energy because of their relatively low insulation level and high window U-factor as compared to commercial buildings. Strip-malls are also affected by climate change because all zones are fully exposed to the outdoors, and the air change rate is relatively high at 1.91 ACH. A comparison of medium and small office buildings shows that their cooling energy increases are generally comparable. Although medium offices have a larger ratio of core zone to total floor area, they have a higher window-to-wall ratio (33%) than that of small office buildings (20%). Furthermore, the building model for small offices has an unconditioned attic which shields the occupied zone from solar radiation and high outdoor temperatures during the summer. The impact of climate change on different types of buildings was influenced by multiple factors, and therefore integrated energy simulations would be more accurate than degree day analysis.

Climate change not only can affect the annual heating and cooling energy consumption, it also has impact on the peak energy use. Figure 7 shows the relative change in peak heating and cooling energy use for a single-family house under three emission scenarios in Chicago. It shows that the relative change in peak heating demand is less than cooling demand. One major reason is that the Coefficient of Performance (COP) of cooling equipment will decrease as outdoor temperature increases, while the boiler heating efficiency is independent of outdoor temperature. Thus, global warming not only increases the cooling load, but also reduces the COP of cooling equipment, thus increase the cooling energy use. It should be noted that neither TMY nor HadCM3 projection is sufficient to represent extreme weather conditions since extreme weather occurs more randomly and is hard to predict through GCM models. Therefore, it would be very likely that the future peak heating and cooling demand exceed the prediction in this paper on the event of sudden abnormal weather such as heat wave or cold storm.

This study also investigated the impact of climate change on the performance of natural ventilation for cooling. Among the cities studied, San Francisco, San Diego, and Seattle are the most suitable, and this paper discusses the results for single-family houses in these three cities. Since natural ventilation for cooling depends on outdoor conditions, it is expected that passive cooling performance will be greatly affected by global warming. We assumed that the indoor

environment is too hot when the air temperature exceeds 26°C. Figure 8 shows the percentage of time in each year when it was too hot indoors from the 1960s to the 2080s under the three emission scenarios. Figure 8(a) shows that in San Francisco, this percentage is always below 8% even under the high emission scenario, and thus natural ventilation will still be suitable by the 2080s. For Seattle, natural ventilation would perform well under the low emission scenario. For San Diego, it would be too hot indoors for 30% of the time under the high emission scenario by the 2080s, which is more than 15 times higher than the percentage in the 2000s. Even under the low emission scenario, the indoor environment would be uncomfortable about 11% of the time. It can be concluded that natural ventilation and cooling would not be suitable by the end of the 21st century in San Diego. Thus, for buildings that are designed to use natural ventilation in San Diego or Seattle, more thermal mass should be added to the buildings in order to counteract the effects of global warming.

To combat the global warming effect, it requires collaboration of designers, building owners and governments. The simplest method for building owners is to adjust the thermostat to use higher cooling setpoint and lower heating setpoint temperature. Also, adding more thermal mass during design phase for natural ventilated buildings would be beneficial since it would reduce the temperature fluctuation and serve as a buffer for a short period of extreme weather. The building code makers could increase the glazing material and envelope insulation requirement to reduce the envelope loss. Also, the ventilation requirement could be more flexible. For example, for advanced ventilation system such as displacement ventilation and underfloor air distribution system, which can provide better IAQ using the same amount of outdoor air due to their favorable air flow pattern[35], the ventilation requirement could be lower than traditional well-mixed system, which will reduce the ventilation load thus reduce building energy consumption.

4. Conclusions

This paper is the first to systematically investigate the impact of climate change on cooling and heating energy consumption in various types of buildings with different cooling modes by EnergyPlus in all 7 climate zones in the U.S. Future weather data was generated by the HadCM3 model for three CO₂ scenarios and downscaled to hourly weather data by use of the Morphing method. An energy analysis was conducted with the EnergyPlus program for nine different types of buildings in 15 cities. This paper found that

- HadCM3 model is capable for generating future TMY data for the U.S. and the accuracy is generally within 10% for projecting TMY2 to TMY3.
- By the 2080s, climate change would increase the annual temperature in the 15 cities by 2.3-7.0 K in comparison to that in the 1960s under the three emission scenarios;
- The majority of the cities located in Climate Zones 1-4 would experience a net increase in source energy use for cooling and heating by the 2080s, while cities in Climate Zones 6 and 7 would experience a net reduction in source energy use;
- The energy simulation showed that the impact of climate change varied greatly among different types of buildings; and
- By the 2080's, the effectiveness of natural ventilation would be greatly reduced by global warming in some cities, such as San Diego.

Acknowledgement

This research was funded partially by the Energy Efficient Building Hub led by the Pennsylvania State University through a grant from the U.S. Department of Energy and other government agencies, where Purdue University was a subcontractor to the grant.

References

- [1] S. Solomon, D. Qin, M. Manning, Z. Chen, M. Marquis, K.B. Averyt, M. Tignor, H.L. Miller, Contribution of Working Group I to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change, Cambridge, United Kingdom, Cambridge University Press, 2007.
- [2] T.R. Karl, J.M. Melillo, T.C. Peterson, Global Climate Change Impacts in the United States, Cambridge University Press, Cambridge, United Kingdom, 2009.
- [3] H. Radhi, Evaluating the potential impact of global warming on the UAE residential buildings - A contribution to reduce the CO2 emissions. Building and Environment 44 (2009) 2451-2462.
- [4] D.H. Rosenthal, H. K. Gruenspecht, E. A. Moran, Effects of global warming on energy use for space heating and cooling in the United States, The Energy Journal 16 (1995) 77-96.

- [5] U.S. Department of Energy, Buildings Energy Data Book, Department of Energy, Washington DC, 2011.
- [6] T.J. Wilbanks, Effects of Climate Change on Energy Production and Use in the United States, DIANE Publishing, Darby PA, 2009.
- [7] D.J. Sailor, Relating residential and commercial sector electricity loads to climate: Evaluating state level sensitivities and vulnerabilities, *Energy* 26 (2001) 645-657.
- [8] P.E. Levy, M.G. R. Cannell, A.D. Friend, Modelling the impact of future changes in climate, CO₂ concentration and land use on natural ecosystems and the terrestrial carbon sink, *Global Environmental Change* 14 (2004) 21-30.
- [9] J.M. Gregory, P.A. Stott, D.J. Cresswell, N.A. Rayner, C. Gordon, D.M.H. Sexton, Recent and future changes in Arctic sea ice simulated by the HadCM3 AOGCM, *Geophysical Research Letters* 29 (2002) 28-1-28-4.
- [10] T.C. Johns, J.M. Gregory, W.J. Ingram, C.E. Johnson, A. Jones, J.A. Lowe, et al., Anthropogenic climate change for 1860 to 2100 simulated with the HadCM3 model under updated emissions scenarios, *Climate Dynamics* 20 (2003) 583-612.
- [11] M. Collins, S.F.B. Tett, C. Cooper, The internal climate variability of HadCM3, a version of the Hadley Centre coupled model without flux adjustments, *Climate Dynamics* 17 (2001) 61-81.
- [12] L.W. Baxter, K. Calandri, Global warming and electricity demand: A study of California, *Energy Policy* 20 (1992) 233-244.
- [13] A.D. Amato, M. Ruth, P. Kirshen, J. Horwitz, Regional energy demand responses to climate change: Methodology and application to the Commonwealth of Massachusetts, *Climatic Change* 71 (2005) 175-201.
- [14] M.J. Scott, D.L. Hadley, L.E. Wrench, Effects of climate change on commercial building energy demand, *Energy Sources* 16 (1994) 339-354.
- [15] S.E. Belcher, J.N. Hacker, D.S. Powell, Constructing design weather data for future climates, *Building Services Engineering Research and Technology* 26 (2005) 49-61.
- [16] M.F. Jentsch, S.B. AbuBakr, A.B.J. Patrick, Climate change future proofing of buildings- Generation and assessment of building simulation weather files, *Energy and Buildings* 40 (2008) 2148-2168.

- [17] A.L.S. Chan, Developing future hourly weather files for studying the impact of climate change on building energy performance in Hong Kong, *Energy and Buildings* 43 (2011) 2860-2868.
- [18] R.L. Smith, B.W. Xu, P. Switzer, Reassessing the relationship between ozone and short-term mortality in US urban communities, *Inhalation Toxicology* 21 (2009) 37-61.
- [19] Y.J. Huang, N. Miller, N. Schlegel, Effects of Global Climate Changes on Building Energy Consumption and Its Implications on Building Energy Codes and Policy in California: PIER Final Project Report, California Energy Commission, Berkeley, CA, 2009.
- [20] Th. Frank, Climate change impacts on building heating and cooling energy demand in Switzerland, *Energy and buildings* 37 (2005) 1175-1185.
- [21] X. Wang, D. Chen, Z. Ren, Assessment of climate change impact on residential building heating and cooling energy requirement in Australia, *Building and Environment* 45 (2010) 1663-1682.
- [22] K. Wan, D. Li, W. Pan, J. Lam, Impact of climate change on building energy use in different climate zones and mitigation and adaptation implications, *Applied Energy* 97 (2012) 274-282.
- [23] M. Olonscheck, A. Holsten, J. P. Kropp, Heating and cooling energy demand and related emissions of the German residential building stock under climate change, *Energy Policy* 39 (2011) 4795-4806.
- [24] D.A. Asimakopoulou, M. Santamouris, I. Farrou, M. Laskari, M. Saliari, G. Zanis, G. Giannakidis et al., Modelling the energy demand projection of the building sector in Greece in the 21st century, *Energy and Buildings* 49 (2012) 488-498.
- [25] ASHRAE Standard 90.1, Energy Standard for Buildings Except Low-Rise Residential Buildings, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., Atlanta GA, 2004.
- [26] Department of Energy, EnergyPlus Engineering Reference: The Reference to EnergyPlus Calculations, Department of Energy, Washington, DC, 2010.
- [27] ASHRAE Standard 62.1, Ventilation for Acceptable Indoor Air Quality, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., Atlanta GA, 2007.

- [28] ASHRAE Standard 62.2, Ventilation and Acceptable Indoor Air Quality for Low-Rise Residential Buildings, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., Atlanta GA, 2007.
- [29] B.A. Thornton, M.I. Rosenberg, E.E. Richman, W. Wang, Y.L. Xie, J. Zhang, et al., Achieving the 30% goal: Energy and cost savings analysis of ASHRAE Standard 90.1-2010. No. PNNL-20405, Pacific Northwest National Laboratory (PNNL), Richland, WA, 2011.
- [30] V. Mendon, R. Lucas, S. Goel, Cost-effectiveness analysis of the 2009 and 2012 IECC residential provisions-Technical support document. Pacific Northwest National Laboratory (PNNL), Richland, WA, 2013.
- [31] ASHRAE Standard 90.2, Energy Efficient Design of Low-Rise Residential Buildings, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., Atlanta GA, 2004.
- [32] H. Wang and Q. Chen, A new empirical model for predicting single-sided, wind-driven natural ventilation in buildings, *Energy and Buildings* 54 (2012) 386-394.
- [33] R. de Dear and G.S. Brager, The adaptive model of thermal comfort and energy conservation in the built environment, *International Journal of Biometeorology* 45 (2001) 100-108.
- [34] M. Deru and P. Torcellini, Source energy and emission factors for energy use in buildings. Technical Report NREL/TP-550-38617, National Renewable Energy Laboratory, Golden CO, 2007.
- [35] A. Novoselac and J. Srebric. A critical review on the performance and design of combined cooled ceiling and displacement ventilation systems, *Energy and buildings* 34 (2002) 497-509.

List of figure captions

Figure 1 3D rendering of building models used in EnergyPlus [29,30]

Figure 2 Comparison of predicted TMY3 data with actual TMY3 data (a) Dry-bulb temperature; (b) dew point temperature; (c) global horizontal solar radiation intensity

Figure 3 (a) Changes in annual temperature for the four selected cities under med emission scenario and (b) Changes in annual temperature for New York under three emission scenarios

Figure 4 Change in annual energy intensity under the three emission scenarios by the 2080s: (a) annual site energy intensity displayed separately for heating and cooling; (b) combined annual heating and cooling source energy intensity

Figure 5 Comparison of energy analysis by the degree day method with that by EnergyPlus (E+) simulations under the medium emission scenario: (a) cooling and (b) heating

Figure 6 Change in cooling energy for different types of buildings

Figure 7 Change in peak heating and cooling energy use for single-family house under three emission scenarios in Chicago

Figure 8 Percentage of time when the indoor air temperature is higher than 26°C with natural ventilation in (a) San Francisco, (b) Seattle, and (c) San Diego

Figure 1
[Click here to download high resolution image](#)

Figure 2

(a)

(b)

(c)

Figure 2 Comparison of predicted TMY3 data with actual TMY3 data (a) Dry-bulb temperature; (b) dew point temperature; (c) global horizontal solar radiation intensity

Figure 3

Figure 3 (a) Changes in annual temperature for the four selected cities under med emission scenario and (b) Changes in annual temperature for New York under three emission scenarios

Figure 4

Figure 4 Change in annual energy intensity under the three emission scenarios by the 2080s: (a) annual site energy intensity displayed separately for heating and cooling; (b) combined annual heating and cooling source energy intensity

Figure 5

(a)

(b)

Figure 5 Comparison of energy analysis by the degree day method with that by EnergyPlus (E+) simulations under the medium emission scenario: (a) cooling and (b) heating

Figure 6

Figure 6 Change in cooling energy for different types of buildings

Figure 7

Figure 7 Change in peak heating and cooling energy use for single-family house under three emission scenarios in Chicago

Figure 8

Figure 8 Percentage of time when the indoor air temperature is higher than 26°C with natural ventilation in (a) San Francisco, (b) Seattle, and (c) San Diego

Table 1 Summary of previous literature on climate change impact on building heating and cooling energy use

Author	Method	Major conclusion
Rosenthal et al. [4]	Residential and commercial in the U.S. Assume 1°C increase by 2010. Degree day method.	1°C increase will reduce energy cost by \$5.5 billion in total U.S. building stock
Amato et al. [13]	Residential and commercial in Massachusetts, U.S. Canadian CGCM1 & HadCM2 for weather projection. Degree day method.	1.2- 2.1% increase in electricity, 7-14% decrease in gas
Scott et al. [14]	Small office building in 4 cities in the U.S. Assumed 3.9 °C temperature increase with and without humidity change. DOE-2 for building simulation	Humidity has large impact on building energy projection.
Jentsch et al. [16]	An office building in Southampton, U.K. HadCM3 projection with Morphing downscaling. TRNSYS for building simulation	Validated the Morphing method. Case study shows natural ventilation still available until 2050 for the studied building.
Chan [17]	Apartment and office building in Hong Kong. MIRCO3_2_MED for weather projection, morphing for downscaling. EnergyPlus for building simulation.	2.6-14.3% for office building; 3.7-24% for residential building in A/C energy increase
Huang et al. [19]	Commercial buildings in California, U.S. HadCM3 for weather projection. Morphing for downscaling. DOE 2.1 for building simulation.	Cooling electricity increased by 50% by 2100 under A1F1, 25% for A2. Peak cooling
Radhi [3]	Residential building in Al Ain, UAE. Assumed 1.6 to 5.9 °C temperature increase. Visual DOE for building simulation.	23.5% cooling electricity increase
Frank [20]	Residential and office buildings in Zurich-Kloten, Switzerland. Assume 0.7-4.4 °C temperature increase. HELLIOS for building simulation.	36-58% decrease in heating demand and 220-1050% increase for cooling demand
Wang et al. [21]	Residential in five regions in Australia. 9 GCM models. Morphing for downscaling. AccuRate for building simulation.	Total energy change -48% to 350% by 2100.
Wan et al. [22]	Office in five cities in China. MIROC3.2-H for weather projection. VisualDOE4.1 for building simulation.	11-20% increase in cooling energy and 13-55% decrease in heating energy.
Olonscheck et al. [23]	Residential building in Germany. Assume 1-3 °C temperature increase. Degree day method.	44-75% decrease in heating. 28-59% increase in cooling
Asimakopoulos et al. [24]	3 types of buildings in Greece. 12 Regional Climate Models for weather projection. Morphing for downscaling. TRNSYS for building simulation	50% decrease in heating, 248% increase in cooling demand by 2100.

Table 2 Cities investigated in this study and their climate zones

City	State	Climate zone	Climate characteristics
Atlanta	Georgia	3A	Warm humid
Baltimore	Maryland	4A	Mixed humid
Chicago	Illinois	5A	Cold
Colorado Springs	Colorado	5B	Cold
Houston	Texas	2A	Hot humid
Las Vegas	Nevada	3B	Warm dry
Madison	Wisconsin	6A	Cold
Miami	Florida	1A	Hot humid
Minneapolis	Minnesota	7A	Very cold
Nashville	Tennessee	3A	Mixed humid
New York City	New York	4A	Mixed humid
Portland	Maine	6A	Cold
San Diego	California	3C	Marine
San Francisco	California	3C	Marine
Seattle	Washington	4C	Mixed marine

Table 3 Types of buildings studied in this paper and selected information [5, 29, 30]

	Total floor area in U.S.	Floor area of building model	Mechanical Ventilation	Infiltration**	Total outdoor air	Occupied hours	Perimeter zone percentage	Window-to-wall ratio	Attic
Unit	$\times 10^6$ m ²	m ²	ACH	ACH	ACH				
Apartment	5,232	3,135	0.37	0.26	0.63	All day	100%	15%	No
Hospital	146	22,422	3.2	0.15	3.35	All day	< 30%	16%	No
Hotel	512	4,013	0.67	0.12	0.79	All day	< 30%	11%	No
Single family youse	16,886	223	0	0.45	0.45	All day	100%	17%	Yes
Medium Office	659*	4,982	1.2	0.19	1.39	7:00-22:00	40%	33%	No
Small Office	659*	511	0.47	0.34	0.81	7:00-22:00	70%	21%	Yes
Restaurant	220	511	6.23	0.91	7.14	6:00-24:00	100%	17%	No
Mall	1,098	2,090	1.37	0.54	1.91	9:00-23:00	100%	10%	No
School	952	6,871	2.4	0.061	2.46	7:00-21:00 during weekdays	< 30%	35%	No

*Because the energy data book [5] does not provide the floor areas for small and medium office buildings separately, this study has assumed that the floor areas of small and medium office building are the same.

** The infiltration rate will be 25% of the value in the table during occupied hours due to the use of mechanical ventilation except single-family house

Table 4 Building envelope and load information

	Commercial Building	Residential
Exterior Wall	<p>Hospital: 200mm Normal weight concrete wall Insulation* 13mm Gypsum</p> <p>The rest of commercial buildings: 25mm stucco 16mm gypsum Insulation* 16mm gypsum</p>	<p>25mm stucco 16mm gypsum Insulation* 16mm gypsum</p>
Roof	<p>9.5mm Built-up roofing Insulation* 0.8mm Metal surface</p>	<p>Apartment: Same as commercial buildings Single-family house: 3.2 mm Asphalt shingles with ceiling insulation* on the attic floor</p>
Exterior floor	<p>200mm Normal weight concrete floor 25mm Carpet pad</p>	<p>Apartment: Same as commercial buildings Single-family house: 19 mm Plywood 25mm Carpet pad</p>
Interior wall	G01 26mm gypsum board	
Interior floor	<p>100mm Normal weight concrete floor 25mm Carpet pad</p>	<p>Apartment: Same as commercial buildings Single-family house: 19 mm Plywood 25mm Carpet pad</p>
Exterior window	<p>Commercial buildings and apartment U value and solar heat gain coefficient based on ASHRAE 90.1 [25] for each climate zone Single family house based on ASHRAE 90.2 [31]</p>	
Internal heat gain	<p>For commercial buildings and apartment, please refer to Thornton et al. [29] for people, lighting, plug load definitions and schedules For single-family house, please refer to Mendon et al. [30] for people, lighting, plug load definitions and schedules</p>	
Heating/cooling setpoints	21/24 °C Setback with 2.7 °C during unoccupied hours	

*Insulation R-value is defined by ASHRAE Standards 90.1 [25] and 90.2 [31] for each climate zone