Electricity Market Games: How Agent-Based Modeling Can Help under High Penetrations of Variable Generation

Integrating increasingly high levels of variable generation in U.S. electricity markets requires addressing not only power system and grid modeling challenges but also an understanding of how market participants react and adapt to them. Key elements of current and future wholesale power markets can be modeled using an agent-based approach, which may prove to be a useful paradigm for researchers studying and planning for power systems of the future.

Giulia Gallo¹

Giulia Gallo is a Director's Postdoctoral Fellow at the National Renewable Energy Laboratory (NREL), conducting research on wholesale electricity markets under high penetrations of renewables. Her research interests include agent-based computational economics, wholesale electricity markets, time-series analysis, and renewables integration. Prior to joining NREL she was a postdoctoral researcher at the Joint Research Centre (JRC) of the European Commission and the University of Genoa. Dr. Gallo holds a Ph.D. in Computer Science, and a M.S. and B.S. in Biomedical Engineering from University of Genoa, Italy.

This work was supported by the U.S. Department of Energy under Contract No. DE-AC36-08GO28308 with NREL. Funding for this report was provided by the National Renewable Energy Laboratory's Laboratory Directed Research and Development Director's Fellowship Program. The author expresses her thanks to Paul Denholm, Greg Brinkman, Ella Zhou and Kara Clark for their helpful comments and reviews, and to Katie Wensuc for her editing.

---

¹ Director's Postdoctoral Fellow at the National Renewable Energy Laboratory

1 Introduction

Electricity market designs govern how market participants generate, sell, buy, and consume electricity and use the electricity infrastructure. The ultimate goal of a well-designed market is to satisfy consumers' demand for electricity at minimum cost by investing in and providing the right quantity and mix of generation resources. Good market design should identify critical issues and address them as simply as possible (Cramton 2003).

It is generally accepted that initial attempts to design and model electricity markets had serious flaws because markets were built and designed by committees of stakeholders and via consensus among interested parties. Inadequate attention was paid to the implications of market power and the ability of market participants to manipulate markets. This led to problems in early markets in the California Independent System Operator (CAISO) and ISO New England (Cramton 2003). Some of the most important and pressing design flaws included the single-settlement methodology, single-part bids, and price discovery mechanisms, which have been addressed by different entities in the United States.

Today, increasingly high shares of renewables are competing with conventional technologies because of their near-zero variable production costs. For many years, markets have relied on baseload and peak generation to provide flexibility to the grid and reliability during times of scarcity, but current market design is flawed and unable to provide the right incentives to build new generation capacity. New models are needed.

Modeling and designing electricity markets must consider elements such as how supply and demand are created and the decisions that involve investing in new generation, retiring old generation, determining which types of generation to operate at a given time, and bidding on generation. In the future, renewables might have a larger impact on market mechanisms and financial outcomes, so there is a need for modeling tools and power system modeling software that can provide policymakers and industry actors with more realistic representations of wholesale markets. These tools and analyses can be represented by agent-based modeling frameworks.

This article discusses how key elements of current and future wholesale power markets can be modeled using an agent-based approach and how this approach may become a useful modeling paradigm to employ when studying power systems of the future. For a more detailed discussion, please refer to (Gallo, 2015b). The rest of the article is organized as follows: Section

2 discusses some of the recent market design challenges that the electricity industry is facing. Section 3 gives an overview of how market manipulation can pose challenges, and it presents some of the most famous cases of market manipulation. Section 4 discusses the agent-based modeling paradigm and how it has been applied to electricity market modeling in the current literature. Section 5 concludes.

2 Gaps in Current Market Design

As the level of renewables on the electric grid increases, price suppressions coming from the deployment of zero-marginal-cost resources such as wind and solar may have a significant impact on the behavior of conventional generators and decision-makers. This contributes to discussions among power system industry actors and those who regulate it about how to design future electricity markets, which are difficult to conceive, model, and implement.

2.1 Merit Order Effect

Recurring discussions in the electric power industry and market design forums are related to the merit order effect, which is the lowering of power prices in an energy market due to an increased supply of renewable energy. This seems to be of greater interest in Europe than it is in the United States because of Europe's higher penetrations of variable generation. High penetrations of renewables have been the focus of electricity market design discussions for some time, and there can be confusion when it comes to how they have changed or presumably will change the dispatch stack of current markets. In many instances, wind and solar power have pushed the merit order curve farther right and caused more expensive, conventional generators to be dispatched less frequently. Consequently, market-clearing prices decrease, either by becoming zero or negative. However, this happens not only when there are high penetrations of renewables; negative prices can also occur in systems that have relatively low penetrations of variable generation because of operational constraints on larger thermal stations.

Sometimes markets clear below zero without intermittent renewable generation as the marginal generator. This phenomenon should be considered a price formation issue of current wholesale electricity markets. These price distortions are caused by how energy policy mechanisms such as production tax credits are used. The effect happens to be "caused" by renewable resources such as wind and solar now, but in theory in the future this effect could be triggered by any generating resource that has low marginal costs.

The average clearing price in any given year in Nord Pool Spot, the leading electricity market in Europe, tends to fall in the range of €20–46/MWh (\$20–50/MWh) (Figure 1). For example, in 2013 60% of the energy was produced by resources that had almost zero marginal production costs, and 23% was from resources that had marginal costs of less than €10/MWh (Figure 1). The Nordic market faces global forces that drive down the electricity price—for example, wet and dry years in Norway and Sweden that determine the availability of hydropower, the amount of wind that generates electricity in Denmark, and the use of different technologies to generate power during winter. These are different from the factors that drive prices down in the United States—for example, shale gas price combined with increased renewables.

Figure 1. (Left) Power generation by source in the Nordic region in 2013 and (right) Nord Pool Spot system prices in 2013. Image from Nordic Energy Regulators (2014)

2.2 Missing-Money Problem

Another example of a market design flaw is the missing-money problem (Stoft 2002). This is a lack of monetary stream that can guarantee a recovery to some generators from their investments to pay for both variable and fixed costs (Ela et al 2014). This affects current market participants. It also affects incentives to build new generation facilities if the electricity prices do not increase because of administrative actions, such as price caps.

The missing-money problem arises for several competing and compelling reasons, and the higher the share of renewables in the current power system, the more pressing this problem is because of the incentives that suppliers of electricity from these sources are facing, which typically suggest that market-clearing prices tend to be driven toward zero (Figure 2). The

missing-money problem was predicted by electricity market theory (Joskow and Tirole 2007, Hogan 2005, Cramton and Stoft 2006).

Figure 2. Illustration of the missing-money problem. *Image by author*

Traditional market designs that try to address the missing-money problem may include longer-term markets such as capacity markets (Cramton and Stoft 2005, Ausubel and Cramton 2010). These markets should incentivize new capacity in locations where it will be most needed in the future, and they differ in product specification, commitment period, and price formation mechanisms. However, when capacity markets were first implemented, in New England, they showed basic and flaws that were unrelated to high penetrations of renewables, as for example the exercise of market power or the way that the level of needed supply was computed (Cramton 2003).

Yet capacity markets can help ensure that there is sufficient generation and provide different sources of revenue streams even in scenarios with high penetrations of renewables. In addition, they can address three pressing problems in current wholesale markets: investment, risk, and market power. Further, the operational challenges posed by growing shares of variable renewable generation can be substantially mitigated through a number of valuable and relatively low-cost measures (Hogan 2012).

A few wholesale market independent system operators (ISOs), including the Electric Reliability Council of Texas (ERCOT) and the Alberta wholesale market, rely on recovering costs from energy and on operating reserves, not capacity, and they employ scarcity pricing signals as a proper price signal to incentivize new generation.

Scarcity pricing allows the price in real time to reach higher levels than the cost of the most expensive marginal generator in the system. These scarcity prices are typically based on administratively set ancillary service scarcity prices, and they vary by region or country. When a system is not able to meet its ancillary service requirements, the administratively set price will be high. Because energy and ancillary services are co-optimized, this price will also be reflected in the energy market. These prices, though difficult to predict in terms of investments in capital, can provide some needed revenue for capacity resources to recover fixed capital costs. Scarcity pricing represents a challenge to ISOs and market design because if the pricing level is inadequate it cannot provide investment incentives to build both conventional generation and renewable energy and transmission infrastructure.

However, scarcity pricing alone might not address the missing-money problem or revenue sufficiency in the future. The missing-money problem has important implications that have more to do with how electricity markets are designed and less with the role that renewables have in making these flaws evident.

2.3 Flexibility and High Penetrations of Variable Generation

Increasing penetrations of variable renewable generation impact the need for flexibility (Ela et al. 2014) and pose challenges to market operators, including variability, uncertainty, and the inherent difficulty in forecasting maximum power output. To mitigate these, new mechanisms have been proposed in many markets to incentivize flexibility in system operations. For example, wholesale market operators can now pay demand response, a nontraditional generating resource, to curtail load (FERC 2011). In ERCOT, nearly half of the contingency reserve neededⁱ is supplied by demand-response resources that curtail when system frequency reaches some level below nominal frequency. Batteries can also provide flexibility, shifting load, providing operating reserves, and thus reducing the cost of operating the power system to a traditional electric utility operating under high penetrations of solar photovoltaic (PV) generation (Denholm et al. 2015). In 2011, CAISO introduced the current flexible ramping constraint mechanism, commonly referred to as “FlexiRamp” (CAISO 2011, Abdul-Rahman et al. 2012). When added to the market clearing engine, it ensures that sufficient ramping capacity is committed and available in the real-time commitment and real-time dispatch process (Ela et al. 2014).

2.4 Uplift Payments

The integration of more renewables coupled with the need for more flexibility in electric power systems has also given rise to more interest in the ability of market participants to obtain revenue streams in the marketplace through uplift paymentsⁱⁱ (Hogan 2006, Gribik et al. 2007). Because of the discrete nature of unit commitment, power plant owners need to consider numerous technical constraints to reliably operate their power plants, and a number of technical and operational limitations impact market outcomes. These conditions do not allow for perfect, complete, full modeling representations of a power system's physical constraints, and when these constraints cause issues they seldom force a system operator to manually dispatch resources that can help resolve them (FERC 2014). On one hand, manual operations help guarantee the reliability of the grid; but on the other hand, they do not reflect the true marginal cost of electricity and can ultimately hinder the economic competitiveness of electricity markets. In 2012, the members of the Market Surveillance Committee of CAISO were asked to provide an opinion on bid cost recovery (BCR) mitigation, because the BCR might provide an incentive for generators to have a strategic behavior aimed at increasing BCR payments (Bushnell et al. 2012). An example is the “incentive, for instance, for a generating unit to receive a day-ahead BCR payment based on a day-ahead commitment, and then to declare an outage so that the unit would not actually run but would still receive the payment, or for a unit to receive BCR for generation in excess of ISO dispatch instructions” (Bushnell et al. 2012). A problem, however, is that uplift payments have been recently gamed.

3 Greed and Market Manipulation

An important piece of market design is to define the set of rules that can prevent gaming and ensure intervention in case manipulations do happen. Electricity markets have several properties that justify some level of intervention by a regulating authority.

When the California electricity crisis of 2001 occurred because of a shortage of electricity supply caused by market manipulations, illegal shutdowns of pipelines by Enron, and capped retail electricity prices, FERC investigated the alleged manipulation of the electricity market by Enron and other energy companies and their role in the crisis. The Enron scandal is probably one of the most known business failures to have happened in the electric power

industry worldwide, and the firm's bankruptcy showed how electricity markets could be gamed to a very dangerous extent.

Prior to the crisis in California, competition policies at FERC had primarily focused on creating competitive market structures that could be relied upon to produce just and reasonable rates. However, in Order 2000 FERC acknowledged that market monitoring was a core function of newly forming regional transmission organizations. In approving the establishment of ISOs in the eastern United States, FERC approved market power mitigation protocols that gave the ISOs limited power to review and regulate generator offer prices under certain conditions, such as situations in which there are local transmission network constraints.

Following the Enron scandal and in the aftermath of the California crisis, FERC gained more oversight on restructured electricity markets in the United States. Based on the Energy Policy Act of 2005, FERC now imposes penalties on entities that manipulate the electricity and natural gas markets. In this regard, FERC (2015) imposed a set of market mitigation rules and subsequent techniques that have been placed in all electricity markets in the United States to prevent additional Enron-like events.

All regulated U.S. ISO markets are also monitored by in-house market-monitoring units—these differ in size, roles, and actions; see Goldman, Lesieutre, and Bartholomew (2004) for a review—and by independent market monitors that are responsible for promoting robust, competitive, and nondiscriminatory electric power markets. The latter typically collect available data; design market metrics; monitor participant conduct, behavior, and market performance; and publish quarterly and annual reports that discuss the overall competitive assessment of each of the monitored markets in the preceding year.

Another recent example of market manipulation is the case of JP Morgan Ventures Energy Corp. (JPMVEC),ⁱⁱⁱ in which uplift payments were used to earn huge profits from the California and the Midwest markets during a two-year period. The strategy that was implemented to game the BCR payments involved some power plants that had previously been running infrequently and at a loss for almost eight months but afterward were running more often and were also very profitable (FERC 2013).

Uplift payments are supposed to allow plants to recover these costs if market revenues are not sufficient to avoid discouraging them from participating during the hours when they are really needed, but they are a concern for many in the industry because there is not disclosure or

transparency about how these payments are made, under which circumstances, or predictable amounts.

Indeed, FERC (2014) has analyzed uplift payments made by the several ISOs from 2009–2013 in an attempt to gain more insight about how and if uplift payments can affect market outcomes and undermine the effectiveness of price signals and reduce market efficiency. The major outcomes of this analysis show that uplift payments are related to the geographical location of resources; they are closely related to energy prices and fuel costs, and they are also related to price divergences between day-ahead and real-time markets.

The strong correlation between uplift credits and price spreads between the day-ahead and real-time markets suggests that the accuracy of commitment decisions may strongly influence uplift and day-ahead and real-time price differences in ISO markets. The need for more accuracy in representing decision-making processes in market design and modeling is paramount, as is a deeper understanding and a possible way of “pre-screening” possible scenarios.

With the increasing complexity in market design and power system operations, it is quite clear that more attention and consideration must be made to the behavioral aspects of electricity markets.

4 Modeling Current and Future Electricity Markets

With the advent of zero-marginal-cost energy sources, market operators and regulatory frameworks are trying to address the related issues for conventional generators either by creating new market structures or by adding more complexities to existing ones. Current electricity markets have singular characteristics compared to other commodities markets, which can affect how participants perceive the market signals needed to contribute to system reliability, offer flexibility into the market, or construct new generation resources.

Standard power system modeling software packages are useful when performing analyses on the existing or predicted future electricity infrastructure, but they are not flexible enough to provide what-if scenarios about how generator behaviors will impact market operations. Traditional research tools for grid industry policymaking that are based on a rational representative agent maximizing its own utility in a general equilibrium framework are unable to accurately predict and cope with some of today’s most pressing challenges, such as renewable portfolio standards.

Integrating increasing penetrations of renewables in current and future power systems is a demanding task that requires technical knowledge of power systems as well as an understanding of the possible decisions that those who operate grids and power plants face every day. Indeed, most renewable integration research that has been conducted to date assumes a future wherein conventional and renewable generators are risk-neutral and offer their true technical capabilities, at their true costs, into large centralized markets for electricity and balancing services. However, historical bids into these markets may reveal insights into strategies from individual participants that influence market outcomes.

Figure 3 shows example bids from generators in ERCOT. The analysis was performed on publicly available day-ahead market disclosure reports available on ERCOT's Web site.^{iv} The left histogram shows the frequency of bids from a simple-cycle gas turbine generator (which has a marginal cost in the range of \$30–\$50/MWh), and the right histogram shows the same information for a coal generator (which has a marginal cost in the range of \$20–\$30/MWh). Although most of the offers for both generators are similar to operational costs, both generators bid much higher than marginal costs 15%–25% of the time.

Figure 3. Example bids from generation in ERCOT during a yearly period. These histograms show that although most bids are clustered around the operational cost of producing energy, some of the bids are many times larger than the marginal costs. Images by author based on data publicly available from ERCOT

The type of real-world market behavior discussed above is typically not captured in research on the grid integration of renewable energy. However, behavioral modeling is necessary to fully capture the impact of the strategic decisions that individual market participants make to influence prices and increase their profits. Behavior modeling can also capture the impacts of strategies driven by risk preferences, complex cost structures, and physical constraints.

Further, planning studies typically assume that generators have either a linear or a polynomial heat rate curve that does not translate into an offer curve. In reality, generators can change their offer bids from one month to another. The two graphs in Figure 4 show how the same generator changed its offer curve in two subsequent months, and the offer curve shown in the right graph does not reflect its marginal costs. Aside from the specific reasons that lead to this type of offer, which are not the focus of this article, these types of dynamic bidding behaviors are not represented in traditional power system modeling studies. Hence, behavioral simulations become crucial to assess how market participants can react to current market mechanisms, institutional changes, and new market rules, and to more accurately represent future markets with high penetrations of variable generation.

Figure 4. Example bids from generation in ERCOT during a yearly period. These two graphs show that a generator changed their offer curves in two months, and (left panel) they bid many times larger than their marginal costs. Images by author based on data publicly available from ERCOT

5 Using Behavioral and Agent-Based Modeling for Electricity Market Design

Electric power systems are changing at a fast pace and becoming increasingly complex from both an economical and a technological viewpoint. This has required system operators and power systems and economics researchers to acquire new competencies and adopt innovative

research approaches to study realistic market scenarios and propose appropriate regulations for the market environment.

Several approaches have been proposed in the electricity market literature. As discussed above, classical analytical power system models do not represent some important market behaviors and outcomes because they are a loose fit to electricity market modeling. Similarly, standard analytical economic approaches that are based on game-theoretic models are usually limited to simplified market simulations among few actors, and they neglect technological and economic constraints such as transmission networks. Further, modeling aspects such as repeated interactions among market operators, market frictions between two or several ISOs, transmission network constraints, incomplete information, and multi-settlement market mechanisms are seldom addressed by literature on electricity market theoretic models. Conversely, computational methodologies offer an appealing approach to cope with the complexity of power market mechanisms by enabling researchers to realistically simulate such market environments.

Agent-based computational economics (Tsfatsion and Judd 2006) modeling is well suited for undertaking institutional studies such as testing current and future electricity market designs. Agent-based computational economics modeling begins with assumptions about “agents” and their interactions and then uses computer software to generate simulations that reveal the dynamic consequences of these assumptions (Tsfatsion and Judd 2006). Agents can range from passive structural features that have no cognitive function to individual and group decision-makers that have sophisticated learning and communication capabilities (Tsfatsion and Judd 2006). Agent-based models are intrinsically designed to handle complex systems, and they allow researchers to construct test beds in the form of computational virtual worlds (Bunn and Oliveira 2003, Conzelmann et al. 2005, Sun and Tsfatsion 2007, Praca et al. 2003, Weidlich and Veit 2008, Cincotti and Gallo 2013). Starting from user-specified initial conditions, world events are driven entirely by agent interactions; the counterexample is given by production cost modeling studies that assume least-cost dispatch as well as no interaction among the agents (i.e., generators, generation companies, load-serving entities) that “populate” their models (Figure 5).

Figure 5. Flowchart of agent-based modeling frameworks. Images from (left) Gallo (2015) and (right) Cincotti and Gallo (2013)

Multi-agent models have been proposed to overcome several shortcomings of current power systems models (Tsfatsion and Judd 2006, Gallo 2015). In these models, agents are heterogeneous, and they are endowed with limited information and computational capabilities. These computational frameworks provide powerful software tools for economics wherein experiments concerning scientific hypotheses and policy design issues can be performed (Tsfatsion and Judd 2006). They address the interactions and the coordination processes of heterogeneous economic agents by means of their individual and social learning mechanisms, the emergence of aggregate statistical regularities in the economy, and the occurrence of market failures—e.g., asymmetric information, imperfect competition, and coordination failures. Consequently, economic multi-agent systems have gained attention during the last decade. In the past few years, a number of studies have pointed out the benefits of agent-based frameworks for economic policy design; see Buchanan (2009), Farmer and Foley (2009), and LeBaron and Winkler (2008).

An agent-based approach can avoid the lack of realism in the optimizing agent assumption by using a realistic description of agent behaviors and interactions. This approach allows us to introduce elements of “behavioral economics.” Increasing literature strands support the evidence of agent-based and heuristic decisions (Kahneman and Tversky 1984, Gigerenzer and Selten 2002). Indeed, agent-based models can represent bounded rational agents with adaptive and learning capabilities (Simon 1955, Kirman 2011). By modeling individual

economic agents on the micro level and aggregating their behavior on the macro level, artificial economies can be constructed that are “richer” than the traditional macro models. The advantages of economic agent-based models are primarily the possibility to model the individual decision-making process of each agent alongside their interactions by means of decentralized market or hierarchical relationships.

Agent-based models have been successfully used to show how the impact of institutional designs changes can affect how market participants behave (Tesfatsion and Judd 2006) and to test how the impact of high penetrations of renewables can affect bidding behaviors as well as the revenues streams of different market participants (Gallo 2015).

Current agent-based test beds (Conzelman et al. 2005, Praca et al. 2003, Weidlich and Veit 2008, Sun and Tesfation 2007, Cincotti and Gallo 2013) have shed light on a variety of electricity market features using test cases and projecting the aggregated results onto existing U.S. and European ISOs. These test beds are limited in their applications by several factors, such as the availability of realistic operational models of wholesale electricity markets or bid data. Gallo (2015) attempted to evaluate the impact of strategic behavior, risk aversion, and increasing levels of renewables and presented the Agent-Based Framework for Renewable Energy Studies (ARES), an integrated research approach that adds an agent-based model of industry actors to PLEXOS and combines the strengths of the two to overcome their individual shortcomings. ARES has been demonstrated by studying how increasing levels of wind could impact the operations and the exercise of market power of representative generation companies that exploit an economic withholding strategy. The analysis was carried out on a test system that represents the ERCOT energy-only market in the year 2020. In particular, the author studied how these generation companies that are deemed to have and exercise market power do so in the ERCOT market by reproducing their decision-making processes. Given the novelty of this modeling approach, the author presented some differences between a standard, least-cost, production modeling simulation and a behavioral one. The agent framework improved the realism of the model as follows: the level of the market prices was higher when strategic resources tried to increase their profits, bidding their true production costs and a markup (Figure 6), and it increased generator profits compared to simple marginal-cost bidding (Figure 7).

Figure 6. Price duration curve comparison between the (left) high demand scenario and (right) low demand scenario. Baseline scenario = B, agent-based scenario = A. Images from Gallo (2015)

The bidding strategy helped the agents to supply less energy but at a higher economic reward. However, the impact of high penetrations of wind reduced the ability of the agents to manipulate the prices and to make profits in the ERCOT market.

Figure 7. Distribution of each agent profits within the simulation. Profits have been normalized by each agent total capacity. Baseline scenario = B, Agent-based scenario = A. Image from Gallo (2015)

The results obtained with the agent framework reproduce with more realism the operations of an energy market under different and increasing wind penetrations. A critical issue for agent-based models is represented by their validation, which is of extreme importance to their success and their usage as a modeling tool. This problem is generic for every researcher engaged

in the behavioral representation of economies. Electricity markets around the world are characterized by distinctive phenomena: these features are typically called stylized facts (LeBaron and Winkler 2008; Weron, Bierbrauer, and Trück 2003). Examples of these features are price jumps or spikes, extreme volatility, seasonality, mean reversion, and an underlying probability distribution that follows power law or is hyperbolic and exhibits heavy tails (see Gallo 2015). Any agent-based model that represents an electricity market should try to mimic these features to reliably and accurately depict reality and to be eventually used to forecast electricity market prices (Cincotti et al. 2014). On the contrary, the purpose of agent-based models is not to predict the future but rather to provide insights into the possible evolution of current and future electricity markets and envisage ranges of possible outcomes and solutions, because the main purpose of modeling per se is not to create an exact replica of all the details of the system under study but to give a realistic representation of it.

6 Conclusions

Integrating increasingly high levels of variable generation in U.S. electricity markets requires addressing not only power system and grid modeling challenges but also an understanding of how market participants react and adapt to them. The need is urgent for modeling tools that can assist and inform policymakers in their decision-making processes, help market design experts evaluate different scenarios, and provide power system operations insight to system planners and operators. A number of technological, modeling and planning barriers stand in the way to more accurately modeling and building power systems under high penetrations of renewable generation, the biggest of which is that effective decision making requires a multidisciplinary approach among all electric power system industry actors. Convincing methods and tools are needed that are able to guide efficient and effective decision-making processes that are capable of detecting emergencies, anticipating future events, and evaluating the impact of different policy choices. If policy makers are able to use these methods and tools to investigate and evaluate different scenarios, they will be more informed, and more informed policy makers lead to better decisions. A combination of production cost modeling simulations and agent-based models can help achieve these goals.

References

- Abdul-Rahman, K., H. Alarian, M. Rothleder, P. Ristanovic, B. Vesovic, and B. Lu. 2012. "Enhanced System Reliability Using Flexible Ramp Constraint in CAISO Market." In *IEEE Power and Energy Society General Meeting Proceedings*. Piscataway, NJ: Institute of Electrical and Electronics Engineers.
- Ausubel, L.M., and P. Cramton. 2010. "Using Forward Markets to Improve Electricity Market Design." *Utilities Policy* 18(4): 195–200.
- Buchanan, M. 2009. "Economics: Meltdown Modelling." *Nature* 460: 680–682.
- Bunn, D., and F. Oliveira. 2003. "Evaluating Individual Market Power in Electricity Markets via Agent-Based Simulation." *Annals of Operation Research* 121: 57–77.
- Bushnell, J., S. Harvey, B. Hobbs, and S.S. Oren. 2012. *Opinion on Bid Cost Recovery Mitigation Measures and Commitment Cost Refinements* (Technical Report). Folsom, CA: Market Surveillance Committee of the California ISO.
- CAISO. 2011. *Opportunity Cost of Flexible Ramping Constraint: Draft Final Proposal* (Technical Report). Folsom, CA. Accessed October 2015: <http://www.caiso.com/Documents/DraftFinalProposal-FlexibleRampingConstraint.pdf>.
- Cincotti, S., and G. Gallo. 2013. "The Genoa Artificial Power-Exchange." In *Agents and Artificial Intelligence*, vol. 358, edited by J. Filipe and A. Fred, 348–363. Heidelberg, Germany: Springer Berlin.
- Cincotti, S., G. Gallo, L. Ponta, and M. Raberto. 2014. "Modeling and Forecasting of Electricity Spot-Prices: Computational Intelligence vs. Classical Econometrics." *AI Communications* 27(3): 301–314.
- Conzelmann, G., G. Boyd, V. Koritarov, and T. Veselka. 2005. "Multi-Agent Power Market Simulation Using EMCAS." In *IEEE Power Engineering Society General Meeting Proceedings* 3, 2,829–2,834.
- Cramton, P. 2003. "Electricity Market Design: The Good, the Bad, and the Ugly." In *Proceedings of the IEEE 36th Annual Hawaii International Conference on System Sciences*. Piscataway, NJ: Institute of Electrical and Electronics Engineers.
- Cramton, P., and S. Stoft. 2005. "A Capacity Market That Makes Sense." *The Electricity Journal* 18(7): 43–54.
- Cramton, P., and S. Stoft. 2006. "The Convergence of Market Designs and Adequate Generating Capacity." White Paper for the Electricity Oversight Board.
- Denholm, P., M. O'Connell, G. Brinkman, and J. Jorgenson. 2015. *Overgeneration from Solar Energy in California: A Field Guide to the Duck Chart* (Technical Report) NREL/TP-6A20-65023. Golden, CO: National Renewable Energy Laboratory.
- Ela, E., M. Milligan, A. Bloom, A. Botterud, A. Townsend, and T. Levin. 2014. *Evolution of Wholesale Electricity Market Design with Increasing Levels of Renewable Generation* (Technical Report) NREL/TP-5D00-61765. Golden, CO: National Renewable Energy Laboratory.
- Farmer, J.D., and D. Foley. 2009. "The Economy Needs Agent-Based Modelling." *Nature* 460: 685–686.
- FERC. 2011. Demand Response Compensation in Organized Wholesale Energy Markets, 134 FERC ¶ 61,187, Order No. 745, FERC Stats. & Regs., March 15. Accessed October 2015: <http://www.ferc.gov/EventCalendar/Files/20110315105757 -RM10-17-000.pdf>.
- FERC. 2013. In re Make-Whole Payments and Related Bidding Strategies (JP Morgan Ventures Energy Corporation), 144 FERC ¶ 61,068.

FERC. 2014. Staff Analysis of Uplift in RTO and ISO Markets, August 14. Accessed October 2015: <https://www.ferc.gov/legal/staff-reports/2014/08-13-14-uplift.pdf>.

FERC. 2015. Petition for Order Affirming the Federal Energy Regulatory Commission's July 2, 2015, Order Assessing Civil Penalties Against City Power Marketing, LLC, and Stephen Tsingas. <http://www.ferc.gov/enforcement/civil-penalties/actions/2015/FERCvCityPower.pdf>.

Gallo, G., 2015. "An Integrated Agent-Based and Production Cost Model for Renewable Energy Studies: Preprint." Presented at the 49th Hawaii International Conference on System Sciences (HICSS), Kauai, HI, January 5-8, 2016.

Gigerenzer, G., and R. Selten. 2002. *Bounded Rationality: The Adaptive Toolbox*. Cambridge, MA: MIT Press.

Goldman, C.A., B.C. Lesieutre, and E. Bartholomew. 2004. *A Review of Market Monitoring Activities at U.S. Independent System Operators* (Technical Report). Berkeley, CA: Lawrence Berkeley National Laboratory.

Gribik, P.R., W. Hogan, and S. Pope. 2007. "Market-Clearing Electricity Prices and Energy Uplift." Working paper.

Hogan, M. 2012. *What Lies "Beyond Capacity Markets"?* (Technical Report). Brussels, Belgium: Regulatory Assistance Project. <http://www.raponline.org/document/download/id/6041>.

Hogan, W. 2005. *On An "Energy Only" Electricity Market Design for Resource Adequacy* (Technical Report). Cambridge, MA: Harvard University.

Hogan, W. 2006. "Revenue Sufficiency Guarantees and Cost Allocation." Comments submitted to FERC, Docket No. ER04-691065.

Joskow, P., and J. Tirole. 2007. "Reliability and Competitive Electricity Markets." *RAND Journal of Economics* 38: 60–84.

Kahneman, D., and A. Tversky. 1984. "Choices, Values, and Frames." *American Psychologist* 39: 341.

Kirman, A., 2011. "Learning in Agent-Based Models." *Eastern Economic Journal* 37: 20–27.

LeBaron, B., and P. Winker. 2008. "Introduction to the Special Issue on Agent-Based Models for Economic Policy Advice." *Journal of Economics and Statistics (Jahrbücher für Nationalökonomie und Statistik)* 228: 141–148.

Nordic Energy Regulators. 2014. *Nordic Market Report 2014: Development in the Nordic Electricity Market* (Technical Report). Accessed November 2015: <http://www.nordicenergyregulators.org/wp-content/uploads/2014/06/Nordic-Market-Report-2014.pdf>.

Praca, I., C. Ramos, Z. Vale, and M. Cordeiro. 2003. "MASCEM: A Multiagent System That Simulates Competitive Electricity Markets." *IEEE Intelligent Systems* 18, 54–60.

Simon, H.A. 1955. "A Behavioral Model of Rational Choice." *The Quarterly Journal of Economics* 69: 99–118.

Stoft, S. 2002. *Power System Economics: Designing Markets for Electricity*. New York, NY: IEEE Press & Wiley-Interscience, John Wiley & Sons, Inc.

Sun, J., and L. Tesfatsion. 2007. "Dynamic Testing of Wholesale Power Market Designs: An Open-Source Agent-Based Framework." *Computational Economics* 30: 291–327.

Tesfatsion, L., and K.L. Judd. 2006. *Handbook of Computational Economics: Agent-Based Computational Economics* vol. 2. Amsterdam: Elsevier.

Weidlich, A., and D. Veit. 2008. "Analyzing Interrelated Markets in the Electricity Sector: The Case of Wholesale Power Trading in Germany." In *IEEE Power and Energy Society General*

Meeting Proceedings: Conversion and Delivery of Electrical Energy in the 21st Century, 1–8. Piscataway, NJ: Institute of Electrical and Electronics Engineers.

Weron, R., M. Bierbrauer, and S. Trück. 2003. *Modeling Electricity Prices: Jump Diffusion and Regime Switching* (Technical Report). Wrocław, Poland: Wrocław University of Technology, Hugo Steinhaus Center, HSC Research Reports.

ⁱ This value is currently approximately 1,500 MW.

ⁱⁱ Uplift payments are payments made to the generators. These are different from uplift charges, which are to be paid by the generators. For a more detailed description, see FERC (2014).

ⁱⁱⁱ See <http://www.wsj.com/articles/SB10001424127887324170004578637662037547582>.

^{iv} See <http://www.ercot.com/mktinfo/reports/index.html>.